

STANDARD BAR SPLICER ASSEMBLY

	Minim	um Lap Leng	ths		
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4	Table 5
3, 4	1'-5''	1'-11''	2'-1''	2'-4''	2'-3''
5	1'-9''	2'-5''	2'-7''	2'-11''	2'-10''
6	2'-1''	2'-11''	3'-1''	3'-6''	3'-4''
7	2'-9''	3'-10''	4'-2''	4'-8''	4'-6''
8 .	3'-8''	5'-1''	5'-5''	6'-2''	5'-10''
9	4'-7''	6'-5''	6'-10''	7'-9''	7'-5''

Table I: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C

Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Table 5: Epoxy bar, Top bar lap, Class B

Threaded splicer bar length = min. lap length + J_2^{l} " + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar síze	No. assemblies required	Table for minimum lap length

Bridge Deck Approach Slab Reinforcement Threaded Threaded splicer bar (E) couplers (E) Bars ररसेलाक लाग Threaded splicer bar (E) 4'-0" 6'-0''

BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required = 212



INSTALLATION AND SETTING METHODS

"A" : Set bar splicer assembly by means of a template bolt. "B" : Set bar splicer assembly by nailing to wood forms or cementing to steel forms. (E) : Indicates epoxy coating.



7 - 1 - 10 USER NAME = tcody DESIGNED - BAN REVISED BAR SPLICER STATE OF ILLINOIS Hutchison Engineering, Inc. PLOT SCALE = NONE CHECKED - JOH REVISED STRUCTURE NO DEPARTMENT OF TRANSPORTATION TAC REVISED PLOT DATE = 8/22/2011 DRAWN Jacksonville & Shorewood, Illinois SHEET NO. 29 OF CHECKED - BAN REVISED v:\bridge\2891-mcdonough\us136\0550063-68418-029-BAR_SPLICER.dgn

BSD-1



STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required		
	1			

NOTES

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi , yield strength.

All reinforcement shall be lapped and tied to the splicer bars. Bar splicer assemblies shall be epoxy coaled according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications. See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

R DETAILS	F.A.P. RTÉ.	SECTION	COUNTY	TOTAL	SHEET NO.
0. 055-0063	315	55-3HB	McDonough	103	60
0.000-0000			CONTRACT	NO. 6	8A40
F 35 SHEETS	ILLINOIS FED. AID PROJECT				