





GENERAL NOTES

See Proposal Booklet for Boring data.

Reinforcement bars shall conform to the requirements of ASTM A706 Grade 60.

The Contractor shall drive one steel HP12x53 test pile in a permanent location at the west abutment and one steel HP14x73 test pile in a permanent location at each pier as directed by the Engineer, before ordering the remainder of piles.

Layout of slope protection system may be varied in the field to suit ground conditions as directed by the Engineer,

Structure Excavation will not be measured for payment but shall be included in the unit price bid for "Concrete Structures" or "Concrete Encasement."

TOTAL BILL OF MATERIAL

ITEM	UNIT	SUPER	SUB	TOTAL
	Cu. Yd.		155.5	155.5
	Cu. Yd.		5.4	5.4
erete	Sq. Ft.	5,225		5,225
	Pound		14,000	14,000
	Foot	388		388
12x53	Foot		369	369
14x73	Foot		992	992
	Foot		1,361	1,361
	Each		1	1
	Each		2	2
	Each		1	1
Special)	Ton		506	506
	Each		2	2

.S & DETAILS	TWP. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
	151	07-02122-01-BR	DOUGLAS	23	6
		CONTRACT NO. 91473			
		ILLINOIS	BOURBON ROAD DISTRICT		
				#	11-540