

F.A.I. RTE.	F.A.I. SECTION			TY	TOTAL	SHE				
90/94	90/94 2003-0311		соок		976	15				
STA.	STA. 1518+00.00 TO STA. 1529+50.00									
FFO. R	LUE E ON TREE CAN	INOIS	EED.	AID	PROJECT					

62583

## NOTES:

- 1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- UNLESS NOTED OTHERWISE, ALL ITEMS AND WORK SHOWN IN HEAVY LINE WEIGHT ON THIS DRAWING ARE PROPOSED ITEMS AND WORK.
- PROVIDE A TEMPORARY POWER FEED TO THE EXISTING SIGN TRUSS STRUCTURE LIGHTING UNITS, SEE DRAWING ME-25 FOR TEMPORARY POWER FEED TO SIGN STRUCTURE DETAILS.
- 4. SPLICE NEW LIGHTING CIRCUIT CABLES TO THE CORRESPONDING EXISTING LIGHTING CIRCUITS LOCATED WITHIN THE EXISTING JUNCTION BOX.
- 5. CONTRACTOR MUST DRILL AN ACCESS HOLE ON THE BOTTOM OF THE EXISTING JUNCTION BOX FOR THE TEMPORARY AERIAL CABLES. PROVIDE A WEATHERTIGHT SEAL WHERE THE AERIAL CABLES ENTER THE JUNCTION BOX.
- 6. PROVIDE A TEMPORARY POWER FEED TO HIGH MAST LIGHT TOWER 7 UCDI. SEE DRAWING ME-16 FOR TEMPORARY ROADWAY LIGHTING WOOD POLE DETAILS.
- PROVIDE A TEMPORARY POWER FEED TO THE TEMPORARY LIGHTING UNIT AT STA. 2530-88. SEE DRAWING ME-16 FOR TEMPORARY ROADWAY LIGHTING WOOD POLE DETAILS.

0 58' 100

RL05-37

CHECKED BY: WDS

REVISIO		ILLINOIS DEPARTMENT OF TRANSPORTATION						
NAME	DATE	F.	A.I. 90/94 (D.	AN RYAN EXPRE	EXPRESSWAY)			
			31s+ STREET TO I-57					
				LIGHTING PLAN				
		SCALE:	1"=50"	DRAWN	BY:	CJM		

DATE: October 29, 2004

CONSOER TOWNSEND ENVIRONME ENGINEERS, INC.
303 EAST WACKER DRIVE, SUITE 600
CHICAGO ILLINOIS 60601-5212, PHONE: (312) 938-0300