

 F.A.I. RTE.	SECTION	COUNTY	TOTAL	SHE
90/94	2003-0311	COOK	976	19
STA.	1518+00.00	TO STA. 1529+50.00		
FFD G	010 DICT 1/0 1 (1) 1	HOLE EED ATD	DOO ITOT	

## 62583

## NOTES:

- 1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. COORDINATE ALL WORK WITH IDOT CONTRACT NOS. 62300 AND 62302.
- UNLESS NOTED OTHERWISE, ALL ITEMS AND WORK SHOWN IN HEAVY LINE WEIGHT ON THIS DRAWING ARE PROPOSED ITEMS AND WORK.
- 4. SEE DRAWING UL-32 FOR 47th STREET UNDERPASS LIGHTING PLANS.
- 5. DETACH THE EXISTING TEMPORARY AERIAL CABLES FROM THE EXISTING LIGHTING UNIT TO BE REMOVED AND REATTACH TO THE NEW TEMPORARY WOOD POLE AS SHOWN. THIS WILL BE INCLUDED FOR PAYMENT WITH THE "REMOVAL OF EXISTING LIGHTING UNIT, SALVAGE" PAY ITEM.
- 6. SPLICE NEW LIGHTING CIRCUIT CABLES TO THE CORRESPONDING EXISTING LIGHTING CIRCUITS LOCATED WITHIN THE EXISTING JUNCTION BOX.
- 7. CONTRACTOR MUST DRILL AN ACCESS HOLE ON THE BOTTOM OF THE EXISTING JUNCTION BOX FOR THE TEMPORARY AERIAL CABLES. PROVIDE A WEATHERTIGHT SEAL WHERE THE AERIAL CABLES ENTER THE JUNCTION BOX.

0 50' 100

RL06-37

DRAWN BY: CJM

A.I. 90/		DATE	NAME	
• ;				
ROA PROPO				
1"=50"	SCALE:			

ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 90/94 (DAN RYAN EXPRESSWAY) 31st STREET TO I-57

ADWAY LIGHTING PLANS OSED IMPROVEMENTS 2006

DATE: October 29, 2004 CHECKED BY: WDS

CTE ENGINEERS CONSOER TOWNSEND ENVIRODYNE ENGINEERS, INC. 303 EAST WACKER DRIVE, SUITE 600 CHICAGO ILLINOIS 60601-5212, PHONE: (312) 938-0300