

PROPOSED UNDERPASS LIGHTING PLAN

RN10

RM10 O

PROPOSED EOR

SINGH & ASSOCIATES, INC. CHICAGO, IL 60606 TEL; (312) 629-0240 FAX: (312) 629-8449

NOTE 5&6

F.A.I. RTE.	SECTION	COUNTY	TOTAL	SHEET NO.
90/94	2003-0311	COOK	976	373
STA.		TO STA.		
FED ROA	DIST NO TILL	NOIS FED AID	PROJECT	-

62583

NOTES

- 1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. LOCATIONS OF EXISTING ELECTRICAL EQUIPMENT SHOWN ON THIS DRAWING ARE APPROXIMATIONS AND SHALL BE VERIFIED IN THE FIELD BY THE CONTRACTOR.
- SPLICE NEW UNDERPASS LIGHTING CIRCUITS TO THE SERVICE CABLES LOCATED IN JUNCTION BOX. SEE DRAWING RLO6-20 AND RLO7-20 FOR CONTINUATION OF UNDERPASS LIGHTING CIRCUIT FEEDS.
- 4. ALL PROPOSED UNDERPASS LUMINAIRES SHOWN ON THIS DRAWING SHALL BE PENDANT MOUNTED OFFSET 2 FEET FROM EDGE OF ROADWAY (EOR) UNLESS NOTED OTHERWISE. SEE DRAWING ME-06 FOR PENDANT MOUNTED UNDERPASS LIGHTING DETAILS.
- SPLICE NEW UNDERPASS LIGHTING CIRCUITS TO THE SERVICE CABLES LOCATED IN JUNCTION BOX. SEE DRAWING RLO6-19 AND RLO7-19 FOR CONTINUATION OF UNDERPASS LIGHTING CIRCUIT FEEDS.
- 6. ALL PROPOSED UNDERPASS LIGHTING UNITS SHOWN ON THIS DRAWING SHALL BE FED FROM IDOT LIGHTING CONTROLLER "R". SEE DRAWING SLO8-05 FOR SINGLE LINE DIAGRAM FOR LIGHTING CONTROLLER "R".
- 7. CONTRACTOR IS RESPONSIBLE FOR THE MAINTENANCE OF THE EXISTING LIGHTING SYSTEM SHOWN ON THIS DRAWING. PROVIDE TEMPORARY POWER AS REQUIRED TO MAINTAIN THE EXISTING LIGHTING SYSTEM.
- 8. COORDINATE ALL ELECTRICAL WORK WITH CIVIL WORK, IDOT CONTRACTS 62304, 62305, 62592, 62593, CONSTRUCTION STAGING AND TRAFFIC CONTROL PLANS.

	JUNCTI	ON BOX SCHEDULE
NO.	SIZE	DESCRIPTION
JB1	6"X6"X4"	STAINLESS STEEL, ATTACHED TO STRUCTURE, UNDERPASS LIGHTING
JB2	12"X10"X6"	STAINLESS STEEL, ATTACHED TO STRUCTURE, UNDERPASS LIGHTING

	CABLE /CONDUIT SCHEDULE
1	3-1/C*10, 1-1/C*10 GND IN 1" DIA PVCC RGC ATTACHED TO STRUCTURE (CKTS AS INDICATED ON THIS DRAWING)
(2)	2-1/C*10, 1-1/C*10 GND IN 1" DIA PVCC RGC ATTACHED TO STRUCTURE (CKTS AS INDICATED ON THIS DRAWING)
3	2-1/C*10, 1-1/C*10 GND IN 1" DIA LIQUID TIGHT FLEXIBLE CONDUIT (CKTS AS INDICATED ON THIS DRAWING)

SEQUENCE OF WORK:

2006: OUTSIDE LANES, NB I-94 AND SB I-94 2007: INSIDE LANES, NB I-94 AND SB I-94



REVISIONS NAME	DATE		. 90/94 318	ARTMENT OF THE COMMENT OF THE COMMEN	EXPRES 1-57 G PLANS	
		SCALE:	1"=20"		DRAWN BY:	VG
REVISED	01/21/05	DATE:	OCTOBER 29,	2004	CHECKED BY:	TM