SECTION COUNTY TOTAL SHEET NO. 9 STA. 1217+00 TO STA. 1230+00 FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT 62583 **→**⊕→ Z - (2) 1/C #2, 1/C #2 GND, 1¹/₄" UD -(2) 1/C #2, 1/C #2 GND, 11/4" UD IN 4" CNC CONCRETE ENCASED (BY OTHERS) ST (2) 1/C #2, 1/C #2 GND, -1¹/₄" UD 92nd S. LAFAYETTE AV. +++++ 7410+00 7408+00 ***** 7404+00 TA. 1230+00 CCTV-09 1217+00 TV-07 DAN RYAN EXPRESSWAY 1225+00 _##= ______ INE ST SHEET 2220+00 MATCHLI SEE MATCHLI SEE S 8754+00 8752+00 8750+00 8748+00 S. STATE ST. (2) 1/C #4, 1-1/C #4 GND, 1¹/₄" UD INSTALL CCTV CABINET DR-10B (NOTE 5)
TOWER NO. OMN1 FUTURE CAMERA LOCATION-(NOTE 4, 6) NOTES: 1. SEE DRAWINGS ME-01 AND ME-02 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS. 2. UNLESS OTHERWISE STATED, ALL NOTED CABLE AND CONDUIT TO BE FURNISHED AND INSTALLED UNDER THIS CONTRACT. 3. THIS SHEET ONLY DEPICTS INSTALLATION OF CLOSED CIRCUIT TELEVISION ELEMENTS. SEE LIGHTING PLANS FOR LIGHTING ELEMENT INSTALLATION. SCALE IN FEET CCTV-08 4. SEE DRAWING COMM-11 FOR CCTV COMMUNICATIONS SYSTEM CONDUIT AND CABLE LAYOUT. ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 94/90 (DAN RYAN EXPRESSWAY) CAMERA DR-106 (SHEET 1 OF 2)

SCALE: 1'-50'

CAMERA DR-108 (SHEET 1 OF 2)

CAMERA DR-108 (SHEET 1 OF 2)

SCALE: 1'-50'

DRAWN BY: DHI 5. SEE DRAWING DT-17 FOR CCTV CABINET MOUNTING DETAILS ON A HIGH-MAST LIGHT TOWER. 6. CONTRACTOR SHALL COIL A MINIMUM OF 20 FEET OF 120-VOLT POWER CABLE AT THE BASE OF THE LIGHT TOWER FOR FUTURE CCTV CAMERA. Edwards

ONE NORTH FRANKLIN
CHICAGO, IL 60606

AND KEICEU

ONE NORTH FRANKLIN
CHICAGO, IL 60606
FAX: (3)21 251-3030
FAX: (3)21 251-3030
WHILEKORPLCOM
WWILEKORPLCOM ^{AND}Kelcey</sup> DATE: October 29, 2004