FED. ROAD DIST. NO. _ ILLINOIS FED. AID PROJECT 62583 EXISTING CABLE TRAY-EXISTING POWER PANEL-PP VIDEO-EQUIPMENT AND RACK NETWORK-EQUIPMENT AND RACK SURVEILLANCE— EQUIPMENT AND RACK SPARE EQUIPMENT— RACK HAR EQUIPMENT-INSTALL NEW CABLE TRAY (MATCH-EXISTING CABLE TRAY MANUFACTURER) ① PP-03 FRONT FRONT FRONT INSTALL DUPLEX OUTLET ON— TOP OF EQUIPMENT RACK (TYP) EXISTING HVAC UNIT -EXISTING 2" PVC STUBOUT - EXISTING 4" PVC STUBOUTS EXISTING CABLE TRAY-EXISTING I-57 SHELTER I-57 SHELTER FLOOR PLAN NOT TO SCALE

NOTES:
1. EQUIPMENT LAYOUT BASED ON PRELIMINARY
SHELTER INSPECTION. CONTRACTOR MAY NEED TO
FIELD LOCATE EQUIPMENT RACKS AND EQUIPMENT.
COORDINATE WITH THE ENGINEER THE FINAL LOCATION
OF ALL EQUIPMENT.
2. CONTRACTOR SHALL MAINTAIN A MINIMUM OF 36" CLEARANCE
WHEN INSTALLING NEW RACKS AND EQUIPMENT.

(1) (2) #12, (1) #12 GND, 3/4" EMT CONDUIT

COMM-95

COUNTY TOTAL SHEET NO.
COOK 976 861

SECTION 94/90 2003-031I COOK

REVISIONS NAME ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 94/90 (DAN RYAN EXPRESSWAY) 31st STREET to I-57 I-57 SHELTER (RO4) EQUIPMENT LAYOUT SCALE: NOT TO SCALE DRAWN BY: DHI DATE: October 29, 2004 CHECKED BY: JEZ

ENVIRUS

ONE NORTH FRANKLIN
CHICACO, IL 60606
AND KEICEU
FAX: G122 251-3015
FAX: G122 251-3015