GENERAL NOTES

- 1. Fasteners shall be AASHTO MI64 Type 1, mechanically galvanized bolts. Bolts ⁷8 in. dia., holes ¹⁵16 in. dia., unless otherwise noted.
- 2. Calculated weight of Structural Steel: AASHTO M270 Gr50 = 454,830 lbs AASHTO M270 Gr36 = 78,080 lbs
- 3. No field welding is permitted except as specified in the contract documents.
- 4. Reinforcement bars shall conform to the requirements of ASTM A 706 Gr 60. See Special Provisions.
- 5. Reinforcement bars designated (E) shall be epoxy coated.
- 6. If the Contractor elects to use cantilever forming brackets on the exterior beams or girders, the brackets shall be placed at the same locations as required for the hardwood blocks in Article 503.06(b) of the Standard Specifications. If additional cantilever forming brackets are required, hardwood blocking shall be wedged between the exterior and first interior beam at each of these additional bracket locations.
- 7. Bearing seat surfaces shall be constructed or adjusted to the designated elevations within a tolerance of l_8 in. (0.01 ft.). Adjustment shall be made either by grinding the surface or by shimming the bearings.
- 8. The existing structural steel coating contains lead. The Contractor shall take appropriate precautions to deal with the presence of lead on this project.
- 9. The Organic Zinc Rich Primer / Epoxy / Urethane Paint System shall be used for painting of new structural steel except where otherwise noted. The entire system shall be shop applied, with the exception of the exterior surfaces and the bottom of the bottom flange of fascia beams, masked off connection surfaces, field installed fasteners and damaged areas shall be touched up and finish coated in the field. The color of the final finish coat for all interior steel surfaces shall be Gray, Munsell No. 5B 7/1. The color of the final finish coat for the exterior and the bottom of the bottom flange of fascia beams shall be Blue, Munsell No. 10B 3/6. See Special Provision for "Cleaning and Painting New Metal Structures."
- 10. The embankment configuration shown shall be the minimum that must be placed and compacted prior to construction of the abutments.
- 11. Slope wall shall be reinforced with welded wire fabric, 6 in. x 6 in. W4.0 x W4.0, weighing 58 lbs. per 100 sq. ft.
- 12. The structural steel plates of the Bearing Assembly shall conform to the requirements of AASHTO M 270 Grade 50.
- 13. If the Contractor chooses to alter the temporary cantilevered sheet piling design requirements shown on the plans, a design submittal including plan details and calculations will be required for review and acceptance by the Engineer.
- 14. The Contractor shall connect the first sheet to the existing abutment wall to ensure stability of sheets driven to the top of the existing footing. This connection shall be reviewed and accepted by the Engineer and included in the cost for Temporary Sheet Piling.
- 15. Slipforming of the parapets is not allowed. Bituminous Coated -Aggregate Slopewall Edge of 2'-0'' -4:1 Welded Wire Fabric 6′′ 📕 \sim 64 SECTION D-D Slopewall shall be reinforced with welded wire fabric, 6 in. x 6 in. - W4.0 x W4.0, weighing 58 lbs. per 100 sq. ft. TYPICAL SECTION THRU SLOPE WALL DESIGNED PMH CHECKED BB DRAWN PMH CHECKED BB

STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION

INDEX OF SHEETS

SR-

SR-1. General Plan and Elevation		
SR-2 General Notes & Total Bill of Material	SR-26	Approach Slab Plan (NB)
SR-3 Construction Staaina	SR-27	Approach Slab Details (NB)
SR-4 Footing Layout	SR-28	SB Framing Plan
SR-5 Top of Slab Elevations 1 of 5	SR-29	NB Framing Plan
SR-6 Top of Slab Elevations 2 of 5	SR - 30	Steel Details
SR-7 Top of Slab Elevations 3 of 5	SR-31	Bearing Details
SR-8 Top of Slab Elevations 4 of 5	SR-32	East Abutment and Details
SR-9 Top of Slab Elevations 5 of 5	SR-33	East Abutment and Details
SR-10 Top of East Approach Slab Elevations (SB)	SR - 34	West Abutment and Details
	SR-35	West Abutment and Details
	SR-36	East and West Abutment Re
	SR-37	Pier 1 (SB)
, , , , , , , , , , , , , , , , , , ,	SR-38	Pier 1 (NB)
	SR-39	Pier 2 (SB)
	SR - 40	Pier 2 (NB)
	SR-41	Piers 1 and 2 Removal
	- SR~42	Temporary Concrete Barrier
SR-18 Drainage System Details SR-19 Drainage Scupper, DS-11	SR-43	Bar Splicer Assembly and M
· · · · · · · · · · · · · · · · · · ·	SR-44	HP Pile Details
SR-20 Diaphragm at East Abutment (SB)	SR - 45	Soil Boring Loas
SR-21 Diaphragm at East Abutment (NB)	SR-46	Soil Boring Logs
SR-22 Diaphragm at West Abutment (SB)	SR-47	Soil Boring and Rock Core
SR-23 Diaphragm at West Abutment (NB)	SR-48	Soil Boring and Rock Core

- SR-24 Approach Slab Plan (SB) SR-25 : Approach Slab Details (SB)





TEMPORARY SHEET PILING FRONT ELEVATION







All drainage system components shall extend to 2'-O" from the end of each wingwall except an outlet pipe shall extend until intersecting with the side slopes. The pipes shall drain into concrete headwalls. (See Article 601.05 of the Standard Specifications and Highway Standard 601101)



(Horiz, dim, @ Rt. 1's)

McDonough Associates Inc. Engineers / Architects	SHEET NO.	F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
130 East Randolph Street Chicago, Illinois 60601 (312) 946-8600	SR-2	57	(46-2) VBR	KANKAKEE	558	329	
	SHEETS		CONTRACT	NO. 66	409		
	SR-48	FED. ROAD DIST. NO. 3 ILLINOIS FED. AID PROJECT					

TOTAL BILL OF MATERIAL

ITEM	UNIT	SUPER	SUB	TOTAL
Removal of Existing Structures No. 1	Each			1
Removal of Existing Structures No. 2	Each			1
Protective Shield	Sq Yd-	1,751		1,751
Structure Excavation	Çu Yd		539	539
Concrete Structures	Cu Yd		1,184.0	1,184.0
Concrete Superstructure	Cu Yd	1,398.0		1,398.0
Bridge Deck Grooving	Sq Yd	3,958		3,958
Concrete Encasement	Cu Yd		19.0	19.0
Protective Coat	Sq Yd-	4,415		4,415
Furnishing and Erecting Structural Steel	L Sum	0.47		0.47
Stud Shear Connectors	Each	16,698		16,698
Reinforcement Bars, Epoxy Coated	Pound	323,326		492,238
Bar Splicers	Each	1,711	448	2,159
Slope Wall 4 Inch	Sq Yd		.148	148
Furnishing Steel Piles HP10x57	. Ft		2,002	2,002
Driving Piles	F†		2,002	2,002
Test Pile Steel HP10x57	Each		2	2
Pile Shoes	Each		52	52
Name Plates	Each	-2		2
Elastomeric Bearing Assembly, Type I	Fach		44	44
Anchor Bolts, 1"	Each		176	176
Geocomposite Wall Drain	Sq Yd		240	240
Bituminous Coated Aggregate Slopewall 6"	Sq Yd		2,109	2,109
Braced Excavation	Cu Yd		1,224	1,224
Porous Granular Embankment, Special	Cu Yd	-	394	394
Drainage Scuppers, DS-11	Each	4		4
Drainage System	L Sum	1		1
Temporary Sheet Piling	Sg Ft		710	710
Pipe Underdrains for Structures 4"	F†	<u> </u>	353	353

<u>Geocomposite</u> /Wall Drain Approach Pavemen Sentextile fabri N | \Bottom of Cap

> Aggregate Drain Pipe

STATION 325+93.10 BUILT 20 ._ BY STATE OF ILLINOIS F.A.I. RT. 57 SEC (46-2) VRR LOADING HS20 STRUCTURE NO. 046-0146

> NAME PLATE See Std. 515001

STATION 325+93.10 BUILT 20 ___ BY STATE OF ILLINOIS F.A.I. RT. 57 SEC (46-2) VBR LOADING HS20 STRUCTURE NO. 046-0147

> NAME PLATE See Std. 515001

GENERAL NOTES & TOTAL BILL OF MATERIAL STRUCTURE NO. 046-0146 (S.B.) & STRUCTURE NO. 046-0147 (N.B.)