

NOTES FOR CCR GROUND BUS RISER

- CONNECTIONS TO GROUND BUS BARS SHALL BE WITH 2-HOLE TONGUE LONG BARREL COMPRESSION LUGS BOLTED TO THE BUS
- CONSTANT CURRENT REGULATORS SHALL BE SHUT OFF PRIOR TO DISCONNECTING EXISTING FRAME GROUNDS AND SHALL REMAIN OFF UNTIL GROUNDING UPGRADES AND NEW GROUND CONNECTIONS ARE
- 3. ALL WORK SHOWN ON THIS SHEET SHALL BE PAID FOR UNDER ITEM AR109200 "INSTALL ELECTRICAL EQUIPMENT" PER LUMP SUM.

2) BY					
	REVISION					
	DATE					
			ITCHEIEID MINICIPAL AIRPORT	LITCHFIELD, ILLINOIS		A.I.P. PROJ.: 3-17-0063-B17
						PROJ.: 3LF-4046

		ļ		
	Filename	Ū	E-605.DWG	
Z	Scale	9	NOT TO SCALE	
· ·	Date	02	02/04/11	
			E-605.DWG	DWG
:5	LAYOUT		KNL	12/14/10
	DRAWN		CWS	12/12/10
	REVIEWED	_	ТΩ	12/22/10

HANS

BUS RISER TAXIWAY "C" EXTENSION GROUND

36