LEGEND PLATE SCHEDULE						
DEVICE	LABEL					
RUNWAY 9-27 & TAXIWAY A CCR	RUNWAY 9-27 & TAXIWAY A					
CUTOUT ENCLOSURE FOR RUNWAY 9-27 & TAXIWAY A	RUNWAY 9-27 & TAXIWAY A					
TAXIWAY B CCR	TAXIWAY B					
CUTOUT ENCLOSURE FOR TAXIWAY B	Taxiway B					
RUNWAY 18-36 & TAXIWAY C CCR	RUNWAY 18-36 & TAXIWAY C					
CUTOUT ENCLOSURE FOR RUNWAY 18-36 & TAXIWAY C	RUNWAY 18-36 & TAXIWAY C					
EACH CUTOUT ENCLOSURE (3 LEGEND PLATES)	CAUTION OPERATE CUTOUTS WITH CCR SHUT OFF					
EACH CUTOUT INPUT SIDE CONNECTION (3 LEGEND PLATES)	INPUT					
EACH CUTOUT OUTPUT SIDE CONNECTION (3 LEGEND PLATES)	OUTPUT					
EACH CONTROL PANEL FOR AIRFIELD LIGHTING AND NAVAIDS (2 LEGEND PLATES)	NOTICE CONTACTORS HAVE REMOTE LOCATED CONTROLS AND MAY ACTIVATE AT ANY TIME					
LOW VOLTAGE WIREWAY (PROVIDE 2 LEGEND PLATES 1/2" HIGH BLACK LETTERS WHITE BACKGROUND)	LOW VOLTAGE					
HIGH VOLTAGE WIREWAY OR PULL BOXES (PROVIDE 2 LEGEND PLATES 1/2" HIGH BLACK LETTERS WHITE BACKGROUND)	HIGH VOLTAGE					

NOTE: LEGEND PLATES SHALL BE WEATHERPROOF ENGRAVED PLASTIC OR PHENOLIC MATERIAL, 1/4" HIGH BLACK LETTERS ON A WHITE BACKGROUND UNLESS NOTED OTHERWISE. SECURE WITH WEATHERPROOF ADHESIVE AND/OR MACHINE SCREWS. FURNISH ADDITIONAL LEGEND PLATES WHERE REQUIRED BY CODE, FOR ADDITIONAL EQUIPMENT, AS DETAILED HEREIN ON THE PLANS, AND AS NOTED IN THE SPECIAL PROVISION SPECIFICATIONS.

FURNISH & INSTALL A WEATHERPROOF WARNING LABEL FOR EACH SAFETY SWITCH, PANELBOARD, LOAD CENTER, CUTOUT, & CONTROL PANEL TO WARN PERSONS OF POTENTIAL ELECTRIC ARC FLASH HAZARDS, PER THE REQUIREMENTS OF NEC 110.16 "FLASH PROTECTION". LABELS SHALL BE HAZARD COMMUNICATION SYSTEMS, LLC (190 OLD MILFORD RD., BOX 1174, MILFORD, PA 18337, PHONE: 1-877-748-0244) PART NO. H6010-9VWHBJ



"DANGER - HIGH VOLTAGE KEEP OUT" SIGN

PROVIDE WARNING SIGN ON VAULT EXTERIOR DOORS LABELED "DANGER - HIGH VOLTAGE - KEEP OUT" PER THE REQUIREMENTS OF NEC 110.34 (C). PROVIDE MINIMUM OF 2 SIGNS (ONE ON EACH DOOR TO THE VAULT).



"DANGER – HIGH VOLTAGE" SIGN

FURNISH AND INSTALL "DANGER - HIGH VOLTAGE" LABELS/SIGNS FOR EACH CUTOUT ENCLOSURE, EACH CONSTANT CURRENT REGULATOR, AND THE HIGH VOLTAGE WIREWAY, TO COMPLY WITH FAA AC 150/5340-26B "MAINTENANCE OF AIRPORT VISUAL AID FACILITIES".

1. PROVIDE PHENOLIC ENGRAVED LEGEND PLATES FOR EACH CONSTANT CURRENT REGULATOR (EXISTING & NEW) NOTING THE RUNWAY AND/OR

2. EACH PLUG CUTOUT CABINET SHALL BE FURNISHED WITH A PHENOLIC ENGRAVED LEGEND PLATE THAT IDENTIFIES THE RESPECTIVE RUNWAY OR TAXIWAY CIRCUIT OR REGULATOR. INCLUDE AN ADDITIONAL LEGEND PLATE LABELED "CAUTION OPERATE CUTOUTS WITH CCR SHUT OFF".

PROVIDE PHENOLIC ENGRAVED LEGEND PLATES FOR THE CUTOUTS TO IDENTIFY THE RESPECTIVE REGULATOR OUTPUT CONNECTION AND THE RESPECTIVE CIRCUIT LOAD CONNECTION.

2	ВУ					
	REVISION					
	DATE					
	Ι_					

LITCHFIELD MUNICIPAL AIRPORT LITCHFIELD, ILLINOIS

HANSON

LEGEND PLATE SCHEDUL TAXIWAY "C" EXTENSION

39