coupler (E)

<del>}</del>

Location

Reinforcement bar -

#### STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths				
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4
3, 4	1'-5''	1'-11''	2'-1''	2'-4"
5	1'-9''	2'-5"	2'-7''	2'-11''
6	2'-1"	2'-11''	3'-1''	3'-6"
7	2'-9"	3′-10′′	4'-2''	4'-8''
8	3'-8''	5'-1''	5′-5′′	6'-2''
9	4'-7"	6'-5''	6′-10′′	7'-9"

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C


Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length +  $1_2^{l}$ " + thread length

\* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length
Deck	#5	16	Table 3
Deck	#6	6	Table 3




#### BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =

JLS	
KWS	
RMG	
KWS	
	RMG

# 11-1-09


STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION



#### INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt. "B" : Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.



## NOTES

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars,

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

### BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS STRUCTURE NO. 016-2519

TOTAL SHEET SHEETS NO.

21

35

F.A.U. RTE. SECTION COUNTY SHEET NO. 10 COOK 3531 1515.1-I 14 SHEETS CONTRACT NO. 60J58 FED. ROAD DIST. NO. | ILLINOIS | FED. AID PROJECT

alfred benesch & company benesch Engineers · Surveyors · Planners 205 North Michigan Avenue, Suite 2400 Chicago, Illinois 8080 Job No. 10032.13