Feb-Ø1-2Ø1Ø 10:56:33AM



STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths							
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4			
3, 4	1'-5''	1'-11''	2'-1''	2'-4''			
5	1'-9''	2'-5''	2'-7''	2'-11''			
6	2'-1''	2'-11''	3'-1''	3′-6′′			
7	2'-9''	3′-10′′	4'-2''	4'-8''			
8	3′-8′′	5'-1''	5′-5′′	6'-2''			
9	4'-7''	6′-5″	6′-10′′	7'-9''			

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C

Table 3. Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + $1_2^{\prime\prime}$ + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length
Deck	#5	32	Table 3
Abutment	#6	12	Table 3



INSTALLATION AND SETTING METHODS

"A" : Set bar splicer assembly by means of a template bolt. "B" : Set bar splicer assembly by nailing to wood forms or cementing to steel forms. (E) : Indicates epoxy coating.

DESIGNED KTH CHECKED ADL DRAWN KTH CHECKED ADL

\$FILE\$

BSD-1

	LJIVEH
& A S S O C	IATES, P.C.
Engineers • Arcl	nitects • Surveyors
] 616 North 24th Street, Burney, IL	Ph (217) 223-3670 - Fax (217) 223-3603
14518 Parıs Gravel Road, Hannıbal, MD	Ph 1573) 221-0020 - Fax (573) 221-0012
] 618 N. 4th Street, Surte 188, Burlington, IA	Ph (319) 753-1636 - Fax (319) 752-3685
] 49 North Prairie Street, Galesburg, IL	Ph (309) 342-4042 - Fax (309) 341-3781
ternet Address	www.klingner.com
STATE OF ILLINOIS D	DESIGN FIRM * 1842738

11-1-09

alternatives.



STANDARD MECHANICAL SPLICER

<u>NOTES</u>

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength

All reinforcement shall be lapped and tied to the splicer bars. Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications. See special provision for Mechanical Splicers. See approved list of bar splicer assemblies and mechanical splicers for

BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS STRUCTURE NO. 001-0055 & 0056

ET NO.11	F.A. RTE.	SECTION				COUNTY	TOTAL SHEETS		SHEET NO.		
	172		1-4B				ADAMS	165		129	
SHEETS						(CONTRACT	N0.	72	A09	
	FED. R	OAD D	IST.	NO.	ILLINOIS	FED.	AID	PROJECT			

Klingner & Associates P.C.