




DUCTBANK INSTALLATION DETAIL ALONG RETAINING WALL NOT TO SCALE




DUCTBANK INSTALLATION DETAIL UNDER PAVEMENT NOT TO SCALE



- 1. SEE DRAWINGS 20/EI-100 AND 20/EI-101 FOR ELECTRICAL SYMBOLS AND ABBREVIATIONS.
- 2. DIMENSIONS SHOWN ON THIS DRAWING ARE TYPICAL FOR MOST INSTALLATIONS. DIMENSIONS AND/OR STATIONS SPECIFIED ON THE PLANS OR HANDHOLE DETAIL DRAWINGS SHALL SUPERCEDE THE DIMENSIONS SHOWN ON THIS DRAWING.
- 3. SEE DRAWING 20/EI-102 FOR CONDUIT DUCTBANK DETAILS.
- 4. STUBOUTS SHALL EXTEND 3' FROM HANDHOLE AND BE CAPPED. NUMBER AND SIZE SHALL BE AS SHOWN ON PLANS. STUBOUTS SHALL BE INCLUDED IN HANDHOLE PAY ITEM AND SHALL NOT BE PAID SEPARATELY.
- 5. FOR DETAILS AT SPECIFIC LOCATIONS, SEE "TYPICAL SECTION DETAILS: EXISTING CROSS STREET OVERPASS FOOTINGS".





DUCTBANK IDENTIFICATION MARKER DETAIL

SCALE: 3" = 1'-0"

20/EI-103

BHP

ILLINOIS	REVISIONS	
F.A.I. 9	DATE	NAME
ELE(IN SH		
SCALE: NOT		

IS DEPARTMENT OF TRANSPORTATION 94 (DAN RYAN EXPRESSWAY)

ECTRICAL DUCTBANK DETAILS HOULDER AND UNDER PAVEMENT

TO SCALE DRAWN BY: DATE: MARCH 7, 2006 CHECKED BY:

SINGH & ASSOCIATES, INC.
CONSULTING ENGINEERS

SINGH & ASSOCIATES, INC.
CONSULTING ENGINEERS

SO W. ADAMS ST.
CHICAGO, IL 60606
TEL: (312) 629-0240
FAX: (312) 629-8449