



PLAN

| NUMBER | LENGTH (FT) | WIDTH (FT) | AREA (SQ YD) |
|--------|-------------|------------|--------------|
| 1 | 1 | 1.5 | 0.2 |
| 2 | 2 | 3 | 0.7 |
| 3 | 2 | 2 | 0.4 |
| 4 | 3.5 | 4 | 1.6 |
| 5 | 1 | 3 | 0.3 |
| 6 | 3 | 3 | 1.0 |
| 7 | 1 | 2 | 0.2 |
| 8 | 2.5 | 4 | 1.1 |
| 9 | 3 | 2.5 | 0.8 |
| 10 | 3.5 | 2 | 0.8 |
| 11 | 2.5 | 5 | 1.4 |
| 12 | 4 | 3 | 1.3 |
| 13 | 1.5 | 4.5 | 0.8 |
| 14 | 1 | 1 | 0.1 |
| 15 | 1 | 3 | 0.3 |
| 16 | 3.5 | 5 | 1.9 |
| 17 | 1.5 | 3.5 | 0.6 |
| 18 | 1.5 | 2 | 0.3 |
| 19 | 2.5 | 2 | 0.6 |
| 20 | 2.5 | 6.5 | 1.8 |
| 21 | 1 | 7 | 0.8 |
| 22 | 3.5 | 9.5 | 3.7 |
| 23 | 3 | 6 | 2.0 |
| 24 | 4.5 | 5.5 | 2.8 |
| 25 | 6 | 12 | 8.0 |
| 26 | 2.5 | 3 | 0.8 |
| 27 | 3 | 2.5 | 0.8 |
| 28 | 5 | 4 | 2.2 |
| 29 | 3 | 4 | 1.3 |
| 30 | 3.5 | 3 | 1.2 |
| 31 | 2 | 3 | 0.7 |
| 32 | 2.5 | 2 | 0.6 |
| 33 | 2.5 | 3.5 | 1.0 |
| 34 | 1.5 | 2 | 0.3 |
| 35 | 2 | 2.5 | 0.6 |
| * 36 | 4 | 4.5 | 2.0 |
| 37 | 3 | 3.5 | 1.2 |
| 38 | 1 | 2.5 | 0.3 |
| 39 | 2.5 | 3 | 0.8 |
| 40 | 1 | 4 | 0.4 |

| NUMBER | LENGTH (FT) | WIDTH (FT) | AREA (SQ YD) |
|--------|-------------|------------|--------------|
| 41 | 3 | 5.5 | 1.8 |
| 42 | 1 | 3 | 0.3 |
| 43 | 2 | 3 | 0.7 |
| 44 | 1 | 3 | 0.3 |
| 45 | 2 | 2 | 0.4 |
| 46 | 7 | 6.5 | 5.1 |
| 47 | 2 | 3 | 0.7 |
| 48 | 1 | 4 | 0.4 |
| 49 | 1.5 | 4.5 | 0.8 |
| 50 | 2.5 | 2.5 | 0.7 |
| 51 | 1.5 | 3.5 | 0.6 |
| 52 | 2.5 | 4.5 | 1.3 |
| 53 | 2.5 | 2.5 | 0.7 |
| 54 | 1 | 2.5 | 0.3 |

Notes: Deck sounding was performed in November 2008. The Resident Engineer will determine final patch locations and quantities in the field before bridge deck patching operations begin.
 * denotes Deck Slab Repair (Full Depth, Type I). Deck Slab Repair (Partial Depth) quantity estimated at 59.7 Sq Yd (Info only).

BILL OF MATERIAL

| Item | Unit | Total |
|-------------------------------|-------|-------|
| Deck Slab Repair (Full Depth) | Sq Yd | 2.0 |
| | | |
| | | |

**DECK SLAB REPAIRS
STRUCTURE NO. 044-0031**