


2. REQUIRED MIN. COMPRESSIVE STRENGTH OF CONC. = 3500 PSI @ 14 DAYS 3. CONTRACTOR MUST SAWCUT EXISTING SIDEWALK AT EXISTING TOOL JOINT

TYPICAL SIDEWALK JOINT LAYOUT



TYPICAL SIDEWALK JOINT DETAIL

APPLIES TO NEW SIDEWALK & SIDEWALK REPLACEMENT

NOTE: ONE-HALF INCH EXPANSION JOINT TO BE PLACED BETWEEN THE SIDEWALK AND ANY STRUCTURE, DRIVEWAY, CURB & GUTTER, ETC.

FILE NAME =	USER NAME = IE Consultants	DESIGNED -	REVISED -			F.A. SECTION	COUNTY TOTAL SHEET
G:\S07009-01\cad\7009-01_Detail01.dgn		DRAWN -	REVISED -	VILLAGE OF SHERMAN	SIDEWALK DETAILS	08-00014-00-SW	SANGAMON 47 9
	PLOT SCALE = 10.0000 '/ IN.	CHECKED ~	REVISED -				CONTRACT NO.93486
	PLOT DATE = 2/12/2009	DATE -	REVISED -		SCALE: SHEET NO. OF SHEETS STA. TO STA.	FED. ROAD DIST. NO. ILLINOIS FED. A	AID PROJECT