

SHEET 5 OF 5 SHEETS

-	-	1111		-	-	SHEET NO.
	117BR-2	EDGA	R	15	10	SHEETS
		-				

## NOTES

Hollow structural steel tubing shall conform to the requirements of A.S.T.M. designation A-500 Grade B Structural Steel Tubing.

All other steel shapes and plates shall conform to the requirements of ALSHTO, M-183 except posts and pioles shall conform to the requirements of AASHTO, M-183 except posts and angles shall conform to AASHTO, M-223, Grade 50. Balts, cap screws, and nuts shall conform to the requirement of ASTM, designation A-307 except for high strength bolts, nuts and washers noted which shall conform to AASHTO, M-164.

All bolts, nuts, cap screws, washers and lock washers shall be galvanized in accordance with AASHTO. M-232.

All posts, railing, rail splices, anchor devices and angles shall be gal-

vanized after shop fabrication in accordance with AASH.T.O. M-III and AST.M. A-385. Galvanized rall shall not be painted. Railing shall be in accordance with Section 508 of the Standard

Specifications, except as noted, and shall be paid for at the contract unit price per lineal foot for STEEL RAILING, TYPE T-1. All field drilled holes shall be coated with an approved zinc rich paint

before erection. The lower portion of the post flange in contact with concrete shall receive two coats of asphalt paint conforming to Section 7/4.08 Type B or place "e" fabric bearing pad between the post and concrete.

The 34" + high strength bolts used to connect the 6 x 4 x 34 angles to the post shall be tightened in accordance with Article 507.04 (g)(3) of the Standard Specifications. The  $1^{-6}$  high strength bolts connecting the angles to the concrete shall be tightened to a snug fit and given an additional 's turn. The  $58^{+6}$  cop screws in bottom of posts shall be tightened to a snug fit only.

a at rail splice	
SPLICE R	ILLINDIS DEPARTMENT OF TRANSPORTATION 3-BARREL BOX CULVERT OVER TRIBUTARY TO BRUSHY FORK CREEK SECTION II7-BR-2 EDGAR COUNTY F.A.P RTE. 836-STA. 135+39
	TYPE T-I STEEL RAILING