



PLAN

MICROSILICA REMOVAL AND REPLACEMENT SEQUENCE (BRIDGE DECK)

Areas 2, 4, & 6 over the pier shall be done before areas 1, 3, 5 & 7 in order to maintain the structural integrity of the negative moment reinforcement bars. At least 72 hours shall have elapsed from the end of the previous pour and the concrete shall have attained a minimum modulus of rupture of 650 psi or a minimum compressive strength of 3500 psi. Care shall be taken not to debond the top mat of negative moment reinforcement during concrete removal. Any deviations from this sequence must be approved by the Engineer prior to removal operations.

DESIGNED - AYV	EXAMINED	DATE -	STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION	MICROSILICA REMOVAL & REPLACEMENT SEQUENCE SN 082-0037		F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.	
CHECKED -	ENGINEER OF STRUCTURAL SERVICES	REVISED				327	JBR-1-1-1	ST. CLAIR	20	18	
DRAWN - AYV	PASSED	ENGINEER OF BRIDGES AND STRUCTURES				SHEET NO. 8 OF 10 SHEETS		CONTRACT NO. T6G41		ILLINOIS FED. AID PROJECT	
CHECKED -											