F.A.I. SECTION 55 99 (1&2) WRS-1 COUNTY MIII 227 106 STA. TO STA. FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT **→**©→Z FIBER OPTIC

UTILITY QUALITY
LEVEL "D"
THE WAS ABLE TO TONE THE
FIBER OPTIC CABLE ON THE
EAST SIDE, OF THE EXPRESSWAY,
BUT ON THE WEST SIDE THE TONE
WAS UNRELIABLE. FIBER OPTIC UTILITY QUALITY LEVEL "B" TBE WAS ABLE TO TONE THE FIBER OPTIC CABLE ON THE EAST SIDE OF THE EXPRESSWAY, BUT ON THE WEST SIDE THE TONE WAS UNRELIABLE. ELECTRIC — UTILITY QUALITY LEVEL "B" The SBC locations depicted have been obtained through the application of geophysical methods to determine the existence and approximate horizontal position of these facilities, However, SBC will not provide TBE Group, Inc. with utility records nor allow access to their field closures (pedestals/manholes etc.), to help verify the locations of their existing underground facilities. Therefore, TBE is unable to verify the completeness of the SBC locations depicted in accordance with the CI/ASCE Standard 38-02. TBE GROUP, INC. CIVIL ENGINEERING * TRANSPORTATION * ENVIRONMENTAL
 * PLANNING * UTILITY ENGINEERINGLOCATING ---: FORCE MAIN TELEPHONE Utilities shown on these plans as depicted in the legend REVISIONS GROUP - WATER ILLINOIS DEPARTMENT OF TRANSPORTATION have been investigated by TBE Group, Inc in accordance with SUE Industry Standards. All other information shown has been provided to TBE Group, Inc by others. Changes to IL09500132, 142, 158, 229, 245 SUE Investigation of Underground Utilities - CTV ---- CABLE TELEVISION TBE SUE PAGE NO: 26 of 29 utilities after dates shown may have been made and therefore I-55/I-80 from US RT. 30 to Weber Road Section No. 99 (182) WRS-1 Contract No. 62895 and 62896 Will County -------- FIBER OPTIC Checked by: Sanda Alexanor_ may result in variances from this plan. Consideration should 205 W. WACKER DRIVE SUITE 1020 CHICAGO, IL 60606 (312) 704-1970 -E---- ELECTRIC be given to updating this plan if deemed advisable prior to final design and construction. Utility Quality Level "A" : Test Holes Utility Quality Level "B" : Designating --TEST HOLE SQL "B" DATE : 1/17/06 SCALE : 1" = 50'