

- 1. ELECTRIC SERVICE SHALL BE OF THE VOLTAGE INDICATED OR DESIGNATED BY THE ENGINEER, AND SERVICE DROP CABLE SHALL BE COMPATIBLE WITH THE SERVICE ACCORDINGLY. SOME INSTALLATIONS MAY CALL FOR SERVICE ENTER CENTRE COUPMENT SUITABLE FOR 3-WIRE SERVICE EVEN THOUGH INSTALLATION OF CORPORATION OF COMPANY OF COMPAN
- 2. THE POLE-MOUNTED ELECTRIC SERVICE BOX DETAIL DEPICTS
  THE BASIC CONSTRUCTION OF THE EQUIPMENT. SLIGHT
  MODIFICATIONS APPLY FOR DIFFERING SERVICES AND
  APPLICATIONS AS FOLLOWS:
  - TYPE A FULLY EQUIPPED FOR 240/120V. 3W SERVICE, COMPLETE WITH LIGHTING MAIN BREAKER
  - TYPE AI FULLY EQUIPPED FOR 240/120V. 3W SERVICE, BLANK COVER IN LIEU OF LIGHTING MAIN BREAKER

  - TYPE B EQUIPPED FOR 120V. SERVICE, COMPLETE WITH 1P, 60A. TRAFFIC SIGNALS MAIN BREAKER
  - TYPE B1 EQUIPPED FOR 120V. SERVICE, COMPLETE WITH 1P, 40A. TRAFFIC SURVEILLANCE MAIN BREAKER
- 3. THE ELECTRIC SERVICE EQUIPMENT ASSEMBLY SHALL BE UL LISTED AS SUITABLE FOR USE AS SERVICE ENTRANCE EQUIPMENT.
- 4. THE ELECTRIC SERVICE EQUIPMENT ENCLOSURE SHALL BE
  NEMA 4X STAINLESS STEEL, NOMINALLY 12'W X 16'H X 8'D, WITH
  A PIANO-HINGED DOOR, STEEL BACK PANEL, FAST-ACTING
  STAINLESS STEEL ENCLOSURE CLAMPS, PADLOCK PROVISIONS
  AND DOOR STOP, HOFFMAN CATALOG NO. A-16H1208SSGLP/A-16
  P12/A-DSTOPK/C-PMK12, OR APPROVED EQUAL.
- 5. CIRCUIT BREAKERS SHALL BE THERMAL MAGNETIC BOLT-ON TYPE WITH A MINIMUM INTERRUPTING CAPACITY OF 25,000 SYMMETRICAL AMPERES AT 240 VOLTS. THEY SHALL BE LOCKABLE IN THE "OFF" POSITION FOR COMPLIANCE WITH OSHA LOCK-OUT/
- 6. THE SURGE PROTECTOR SHALL BE SUITABLE FOR 240/120 VOLT SINGLE PHASE 60HZ AC ELECTRICAL SERVICE, WITH A SURGE ENERGY CAPABILITY OF 2160 JOULES OR BETTER AT BAZO MICROSECONDS, RATED -40 TO 60 DEGREES C., WITH LED OPERATING INDICATORS, AND SHALL BE U. LISTED PER UL 1449, CUTLER-HAMMER CMOV230L065XST OR APPROVED EQUAL.
- 7. BUS BARS, CONNECTORS, AND LUGS SHALL BE COPPER, INSULATED AND ISOLATED, AND CONFIGURED TO PREVENT SHORTED CONDITIONS FROM TIGHTENING TERMINATIONS, ETC. THE OVERALL BUS SECTION SHALL BE CONFIGURED BEHIND AN INSULATING BARRIER SHIELD WHICH IS REMOVABLE FOR ACCESS TO CONNECTIONS, OR THE ASSEMBLY SHALL BE A MANUFACTURED SPECIALTY PANELBOARD, CUTLER-HAMMER PRL2A OR APPROVED FOLMS.
- 8. THE COMBINATION GROUND AND NEUTRAL BAR SHALL BE CONFIGURED WITH SEPARATE GROUND AND NEUTRAL SECTIONS AND SPARE TERMINALS AS INDICATED. THE HEADS OF GROUND SCREWS SHALL BE PAINTED GREEN. THE HEADS OF NEUTRAL SCREWS SHALL BE PAINTED WHITE. THE SERVICE NEUTRAL AND SERVICE GROUNDING ELECTRODE CONDUCTOR SHALL BE TERMINATED ADJACENT TO EACH OTHER AT THE DIVIDE BETWEN THE SECTIONS AND WIRTNG SHALL BE TERMINATED ONLY UPON THE APPROPRIATE SECTION.
- 9. THE WIRING TERMINALS, INCLUDING THE GROUND/NEUTRAL BAR SHALL BE ARRANGED TO PROVIDE ADEQUATE ROOM FOR PERFORMING FIELD TERMINATIONS.
- 10. A PLASTIC LAMINATED LAYOUT AND CIRCUIT DIAGRAM SHALL BE MECHANICALLY SECURED TO THE INTERIOR SIDE OF THE ENCLOSURE DOOR.
- 11. A 2-COLOR ENGRAVED PLASTIC NAMEPLATE, ATTACHED WITH SCREWS, AND ENGRAVED AS INDICATED, SHALL BE PROVIDED FOR EACH MAIN BREAKER.
- 12. LUGS AND CONNECTORS SHALL BE RATED FOR 75°C CONDUCTOR.
- 13. THE EXACT MOUNTING HEIGHT OF THE BOX SHALL BE FIELD DETERMINED TO AVOID OBSTRUCTIONS AND PUBLIC ACCESS. TYPICAL HEIGHT SHALL BE APPROXIMATELY 10 FEET ABOVE GRADE.

## **COMBINATION LIGHTING & TRAFFIC POLE** MOUNTED ELECTRIC SERVICE BOX DETAIL

FILE NAME = JSER NAME = ZACH WALLSTEN REVISED - R. TOMSONS 08-13-04 DESIGNED -4085.877 - TR1.dwc DRAWN REVISED CHECKED REVISED PLOT DATE = 3/22/2012 DATE REVISED

STATE OF ILLINOIS **DEPARTMENT OF TRANSPORTATION** 

**COMBINATION LIGHTING & TRAFFIC POLE** MOUNTED ELECTRIC SERVICE BOX DETAIL SCALE: N.A. SHEET NO. OF SHEETS STA.

FAP. RTE SECTION COUNTY /ARIES 2011-209-TS COOK 52 51 CONTRACT #: 60R47 BE-230