

METAL SHELL PILE TABLE

Designation and outside diameter	Wall thickness t	Weight per foot (Lbs./ft.)	Inside volume (yd. ³ /ft.)
PP12	0.179′′	22.60	0.0274
PP12	0.250''	31.37	0.0267
PP14	0.250″	36.71	0.0368
PP14	0.312″	45.61	0.0361



DETAIL A



-Metal shell piles

WELDED COMMERCIAL SPLICE



END PLATE ATTACHMENT



When called for on the plans, the Contractor shall furnish metal shell pile shoes consisting of a single piece conical pile point as shown. The pile shoes shall be cast in one piece steel according to either ASTM A 148 Grade 90-60 or AASHTO M 103 Grade 65-35 and shall provide full bearing over the full circumference of the metal shell pile. The pile shoe shall have tapered leads to assure proper alignment and fitting and shall be secured to the pile with a circumferential weld.

METAL SHELL PILE SHOE ATTACHMENT

(See Note A)



COMPLETE PENETRATION WELD SPLICE

* Field fabricated backing ring may be made from pile shell by removing segment to allow reducing circumference and vertically rejoin with partial joint penetration weld.



Note: The metal shell piles shall be according to ASTM A 252 Grade 3.

F-MS	7-1-10			ASTM A 252 Grade 3.	ASTM A 252 Grade 3.		
Р	USER NAME =	DESIGNED -	REVISED -	Allen Henderson & Associates, Inc.	METAL SHELL PILE DETAILS		
		CHECKED -	REVISED -	Civil and Structural Engineers Springfield, IL.			
	PLOT SCALE =	DRAWN -	REVISED -	62703 Phone: (217)544–8033 IL. Design Firm	STRUCTURE NO. 065–3125		
	PLOT DATE =	CHECKED -	REVISED -	No. 184001907	SHEET NO. 6 OF 6 SHEETS		