

STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths					
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4	Table 5
3, 4	1'-5''	1'-11''	2'-1"	2'-4"	2'-3"
5	1'-9''	2'-5"	2'-7"	2'-11''	2'-10''
6	2'-1''	2'-11''	3'-1''	3'-6"	3'-4"
7	2'-9''	3'-10''	4'-2"	4'-8''	4'-6''
8	3′-8′′	5′-1′′	5′-5″	6'-2"	5′-10′′
9	4'-7"	6′-5′′	6'-10''	7′-9′′	7′-5′′

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C

Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Table 5: Epoxy bar, Top bar lap, Class B

Bridge Deck

Threaded

couplers (E)


ecconomic and the second

Reinforcemen

Threaded splicer bar length = min, lap length + l_2^{l} " + thread length


* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.


Location	Bar		Table for minimum
LUCGITUIT	size	required	lap length
Deck	#5	16	Table 3
Deck	#6	8	Table 3



INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt. "B" : Set bar splicer assembly by nailing to wood forms or cementing to steel forms. (E): Indicates epoxy coating.





STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required

Approach Slab

6'-0"

Threaded splicer

bar (E)

BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =

NOTES

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi

All reinforcement shall be lapped and fied to the splicer bars.

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications. See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

RSD-1

7-1-10

Threaded splicer bar (E)

D_{ζ}		7 - 1 - 10		
STORE AND ADDRESS	LIN ENGINEERING,LTD. Consulting Engineers	USER NAME =	DESIGNED - TBP	REVISED -
		FILE NAME =	CHECKED - ADB	REVISED -
		PLOT SCALE =	DRAWN - AJF	REVISED -
SSEE SEE	Chatham, Illinois	PLOT DATE =	CHECKED - MTH	REVISED -

STATE OF ILLINOIS **DEPARTMENT OF TRANSPORTATION** BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS STRUCTURE NO. 016-0218 SHEET NO. 7 OF 7 SHEETS

	F.A.P. RTE.	SECTION	COUNTY	TOTAL	SHEE NO.	
	345	8R-1-RS-4	COOK 124		100	
_			CONTRACT	NO. 6	OM46	
		ILLINOIS FED. AL	ID PROJECT			