

(a) (b) (c) (d)

 $(2)\ 24$ awg. Shielded twisted pair with a common, meeting eigrs-485 applications or as required by aloms manufacturer. CAT 6 DATA LINE IN CONDUIT TYPICAL U.O.N. COORDINATE ALL WORK WITH ALCMS MANUFACTURER (CONSTANT CURRENT REGULATOR MANUFACTURER). PROVIDE ALL REQUIRED DATA CONNECTION LINKS.

PROVIDE ALL REQUIRED DCME FOR REIL CONTROL PANEL. PROPOSED ALCMS SHALL CONTROL AND MONITOR REIL 16, REIL 34, REIL 12, AND REIL 30 CIRCUITS.


COORDINATE ALL RADIO INTERFACING EQUIPMENT WITH OWNER. PROVIDE ALL NETWORK INTERFACING HARDWARE AND EQUIPMENT. INCLUDING SOFTWARE AND PROGRAMMING.

PROVIDE ALL REQUIRED TRANSCEIVER AND INTERFACING PANEL FOR LAHSO CONTROL PANEL.

2 #10 THWN, 1 #12 GND. UPS POWER TO ACE-II UNITS

ω 4

- (2) \odot NEW DISTRIBUTED CONTROL AND MONITORING EQUIPMENT, DCME, COMBO AS MANUFACTURED BY SIEMENS OR EQUAL. MICROPROCESSOR BASED CONTROL/MONITOR PANEL WITH REMOTE AND LOCAL CONTROL FOR CCR STATUS, DIMMING CONTROL AND CABLE INSULATION MONITOR.
- PROVIDE ALL REQUIRED TRANSCEIVER AND INTERFACING PANEL FOR REMOTE BEACON CONTROL. INSTALL PROPOSED LIGHTING CONTACTOR AND ACE—II FOR BEACON CONTROLS UNDER COUNTER IN ATCT CAB. THE EXACT LOCATION SHALL BE COORDINATED WITH THE FAA. COORDINATE NETWORK INTERFACING EQUIPMENT WITH GENERATOR AND TRANSFER SWITCH MANUFACTURER. PROVIDE ALL NETWORK INTERFACING HARDWARE AND EQUIPMENT.



AIRFIELD LIGHTING AND EQUIPMENT CONTROL DIAGRAM
NOT TO SCALE

AIRFIELD LIGHTING VAULT

 Θ

Θ

 Θ

Θ

DCME

DCME Θ

→ PM

 \odot

DCME \odot

DCME Θ

DCME

 Θ

O DCME

O DCME

 Θ

 \odot

 Θ

DCME

DCME Θ

DCME

DCME

SPARE CCR

TAXIWAY A,B,E,F CCR

TAXIWAY CCR

SPARE CCR

TAXIWAY C CCR

CCR

CCR

∞

FUTURE

FUTURE

LAHSO CONTROLLER

REIL CONTROLLER

AUTOMATIC TRANSFER SWITCH

REDUNDANT --DATA NETWORK

LIGHTING VAULT

VAULT DATA RACK

@