June 8, 2022

SUBJECT: Route FAS 410A (CH 4)

Section 17-00137-00-BR

Warren County Contract No. 89760

Item 199

June 17, 2022 Letting

Addendum A

NOTICE TO PROSPECTIVE BIDDERS:

Attached is an addendum to the plans or proposal. This addendum involves revised and/or added material.

- 1. Revised the Index to the Special Provisions
- 2. Revised page 13 to the Special Provisions.
- 3. Added page 31A to the Special Provisions.

Prime contractors must utilize the enclosed material when preparing their bid and must include any changes to the Schedule of Prices in their bid.

Very truly yours,

Jack A. Elston, P.E.

Bureau Chief, Design and Environment

SPECIAL PROVISIONS INDEX

ITEM	PAGE #
DESCRIPTION OF WORK	1
PROJECT LOCATION	1
PUBLIC SAFETY AND CONVENIENCE	1
JOINT UTILITY LOCATING INFORMATION FOR EXCAVATORS	1
EXISTING UTILITIES	2
BORROW AREAS, USE AREAS, AND/OR WASTE AREA	2
BORING DATA	2
BRIDGE SHOP DRAWINGS	3
COMMITMENTS	3
ORDERING LENGTH CONFIRMATION – DRAINAGE ITEMS	3
ENVIRONMENTAL REVIEWS	3
TRAFFIC CONTROL PLAN	4
UTILITIES	7
EARTH EXCAVATION	7
BORROW AND FURNISHED EXCAVATION	8
SUBGRADE TREATMENT	9
EMBANKMENT (RESTRICTIONS)	10
EMBANKMENT	11
AGGREGATE QUALITY	11
GRANULAR BACKFILL FOR STRUCTURES	12
STONE RIPRAP, CLASS A5	12
REMOVAL OF EXISTING STRUCTURES	13
PROTECTIVE COAT	13
SEEDING, CLASS 2 (SPECIAL)	13
TRAFFIC BARRIER TERMINAL TYPE 2	14
STEEL PLATE BEAM GUARD RAIL, (SHORT RADIUS)	14
HOT MIX ASPHALT SURFACE REMOVAL (VARIABLE DEPTH)	14
PROOF ROLLING	15
PCC AUTOMATIC BATCHING EQUIPMENT	15
PCC PLACEMENT BY PUMP REQUIREMENTS	
PCC SUPERSTRUCTURE AGGREGATE OPTIMIZATION	
PCC QC/QA ELECTRONIC REPORTS SUBMITTAL	
U.S. ARMY CORPS OF ENGINEERS SECTION 404 PERMIT	
LR107-4 - INSURANCE	26
LR702 - CONSTRUCTION AND MAINTENANCE SIGNS	27
LR1030-2 - LOCAL QUALITY ASSURANCE/QUALITY MANAGEMENT QC/QA	28
IDOT TRAINING PROGRAM GRADUATE ON-THE-JOB TRAINING	30
AGGREGATE DITCH	31Δ

REMOVAL OF EXISTING STRUCTURES

Description. The work shall be performed in accordance with Section 501 of the Standard Specifications and as specified below.

The Contractor shall remove the wall portions of the existing abutments and piers to the final grade as required to construct the proposed substructure units.

Basis of Payment. This work shall be included in the contract price each bid for REMOVAL OF EXISTING STRUCTURES and no additional compensation will be allowed.

PROTECTIVE COAT

Description. This work shall be done in accordance with Section 503 and Article 503.19 of the Standard Specifications and with the exception of the materials described herein. The deck surface, slab fascia, pier and abutment end of caps, and abutment wingwalls shall be coated.

Basis of Payment. This work will be paid for at the contract unit price per square yard for PROTECTIVE COAT and no additional compensation will be allowed.

SEEDING, CLASS 2 (SPECIAL)

Description. This work shall be done in accordance with Section 250 and 251 of the Standard Specifications and the following provisions.

Materials. The fertilizer nutrients shall be applied at a rate of 420 pounds of actual nutrients per acre. The fertilizer furnished shall be a ready mixed material having a ratio of (1-4-2).

When seed or fertilizer is applied with a hydraulic seeder the rate of application shall be not less than 500 gallons of slurry per acre.

Construction Requirements. Mulching seeding areas shall be done in accordance with Article 251.03b (Method 2, Procedure 1 or Procedure 2). Mulch for Method 2, Procedure 2 shall be applied at a rate of 2 tons per acre.

Basis of Payment. This work shall be paid for at the contract unit price per acre of SEEDING, CLASS 2 (SPECIAL). The items of Mulch and Fertilizer Nutrients will not be paid for separately but shall be included in the contract unit price per acre for SEEDING CLASS 2 (SPECIAL).

AGGREGATE DITCH

Description. This work shall consist of furnishing, transporting and placing riprap as shown in the details included with the plans. This item shall be constructed in accordance with the applicable portions of Sections 283 and 1005 of the Standard Specifications.

Gradation. The material used for riprap shall conform to Gradation Number 3 of Article 1005.01(c) of the Standard Specifications.

Construction Requirements. The stone riprap ditch shall be constructed as one layer of stone without bedding material. The layer shall be a minimum of 12 inches thick and to the lines and grades as shown on the plans, or as directed by the Engineer.

The placement of the stone shall begin at the lower elevation and proceed up the slope in such a manner as to construct a reasonably well graded mass of stone free from objectionable pockets of small stones and clusters of large stones. Re-arranging of individual pieces may be done by mechanical methods.

Filter fabric is not required.

Basis of Payment. The stone riprap ditch shall be measured in tons and paid for at the contract unit price per ton for AGGREGATE DITCH, which price shall include all labor and materials required to complete the work in place.

AGGREGATE DITCH SPL JANUARY 11, 2014 Section 281