

2. REQUIRED MIN. COMPRESSIVE STRENGTH OF CONC. = 3500 PSI @ 14 DAYS 3. CONTRACTOR MUST SAWCUT EXISTING SIDEWALK AT EXISTING TOOL JOINT

GROOVE 1/8 - 1/4 AT 5' INTERVALS 3/4 EXPANSION JOINT AT 100' INTERVALS

TYPICAL SIDEWALK JOINT DETAIL

APPLIES TO NEW SIDEWALK & SIDEWALK REPLACEMENT

ONE-HALF INCH EXPANSION JOINT TO BE PLACED BETWEEN THE SIDEWALK AND ANY STRUCTURE, DRIVEWAY, CURB & GUTTER, ETC.

TYPICAL SIDEWALK JOINT LAYOUT

FILE NAME =	USER NAME = IE Consultants	DESIGNED -	REVISED -		SIDEWALK DETAILS			F.A.	SECTION	COUNTY	TOTAL SHEET	
G:\S07009-01\cad\7009-01_Deta:101.dgn		DRAWN -	REVISED -	VILLAGE OF SHERMAN				IXTLA	08-00014-00-9	SW SANGAMON	JN 47 9	
	PLOT SCALE = 10.0000 '/ IN.	CHECKED -	REVISED -					1		CONTRAC		
	PLOT DATE = 2/12/2009	DATE -	REVISED -		SCALE:	SHEET NO. OF	SHEETS STA.	TO STA.	FED. ROA	AD DIST. NO. ILLINO	IS FED. AID PROJECT	