



VIEW B-B



See sheet S-8 for scupper location relative to parapet.



SECTION C-C

 l_{g} " R typ.

BOLT HOLE DETAIL

11-1-06





SECOND VANE DETAIL

BILL OF MATERIAL								
ITEM	UNIT	QUANTITY						
Drainage Scupper, DS-33	Each	2						



DS-33

F.A.I. RTE.	SECTION		COUNTY		TOTAL SHEETS	SHEET NO.		
59	•		WILL		608	356		
STA. TO STA.								
FED. R	DAD DIST. NO. 1	ILL INOIS	FED.	AID	PROJECT			
• (26, 26HB-1 & 114) R-2 CONTRACT NO. 60363								

Notes:

All cast iron parts shall be gray iron conforming to the requirements of AASHTO M 105, Class 35B.

Bolts, anchor studs, washers and nuts shall conform to the requirements of ASTM A 307 and shall be galvanized according to AASHTO M 232.

Downspouts located on the exterior side

of a painted steel fascia beam shall be painted with the finish coat specified for the exterior side of the fascia beam. As an alternate bolts anchor studs washers and nuts may l

As an alternate, bolts, anchor studs, washers and nuts may be stainless steel according to Article 1006.29(d) of the Standard Specifications.

Structural steel weldments of equal sections and of the same configuration may be substituted for the cast iron scupper frame. Fillet or full penetration welds shall be used for the weldments. Details shall be submitted to the Engineer for approval. Structural steel weldments shall not be substituted for the cast iron scupper grate. Structural steel frames and downspouts shall be galvanized according to AASHTO MIII. The construct shall the gaproaritet measures to accura that

The Contractor shall take appropriate measures to assure that Protective Coat is not applied to the scupper.

Cost of the Grate, Frame, Downspout, Anchor Studs, Bolts, Washers and Nuls including complete installation of the scupper shall be paid for at the contract unit price each for Drainage Scupper, DS-33.

Alternate fiberglass downspout conforming to ASTM D 2996 with a short-time rupture strength hoop tensile stress of 30,000 psi min, may be used in lieu of the cast iron or steel equivalent.

