

RAMPED SIDEWALK


TYPICAL RAMP WITH FULL WALK
10 FEET WIDE OR LESS

¾" P.J.F.

3/4" P.J.F.-

BACK OF SIDEWALK

TYPICAL RAMP WITH FULL WALK GREATER THAN 10 FEET WIDE



TYPICAL RAMP ADJACENT TO PARKWAY


RAMP SLOPE


DESIRABLE MAXIMUM 1" PER FOOT ABSOLUTE MAXIMUM 11/2" PER FOOT

* FLARE SLOPE


DESIRABLE MAXIMUM 3" PER FOOT MINIMUM WIDTH OF FLARE 1 FOOT

** 7" SIDE CURB





TYPICAL SECTION
AT GUTTER



LEGEND

PREFORMED JOINT FILLER

DUMMY JOINT
---- SLOPE BREAKPOINT
• FLARED CURB


** 7" SIDE CURB


♦ DEPRESSED CURB

NOTES:

PREFORMED JOINT FILLER SHALL BE PLACED AS NOTED IN STANDARD DETAILS FOR SIDEWALK CONSTRUCTION.

THIS STANDARD SHOULD BE CONSIDERED TYPICAL FOR MOST LOCATIONS. THERE MAY BE SPECIAL INSTANCES WHERE DESIGN CHANGES WILL BE REQUIRED.





CTE | AECOM

3 OF 5