

Proposed water main below existing sewer line with 18"

Omit Select Granular Cradle and Granular Backfill to one (1) foot over top of pipe and use Select Excavated Material (Class IV) and compact for 10 feet on either side of sewer line.


If Select Granular Backfill exists, remove within width of Existing Sewer Line trench and replace with Select Excavated Material (Class IV) and compact.


Provide adequate Support for Existing Sewer Line to prevent damage due to settlement.


EXISTING SEWER LINE

NOTE: CLASS IV MATERIAL SHALL BE COMPACTED TO 95% OF STANDARD PROCTOR MAXIMUM DENSITY.

minimum separation.







Plotted: May 27, 2008 @ 4:07 PM By. Terri Seidler-Johnson - Tab: 156 DETAILS (22x34)