

NOTE:

PROPOSED ELECTRICAL ONE-LINE DIAGRAM FOR VAULT AND AIRFIELD (CONTINUED)

^{1.} PROVIDE BOOST TRANSFORMER FOR EACH VASI CIRCUIT WHERE VOLTAGE DROP FROM VAULT TO VASI PCU EXCEEDS 5%. BOOST TRANSFORMER SHALL BE INSTALLED IN THE VAULT. EXISTING BOOST TRANSFORMERS MAY BE RELOCATED TO NEW VAULT WHERE DETERMINED SUITABLE FOR USE.