F.A.P. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
066	21 (B&G) R	MCHENRY	66	29
STA.		TO STA.		
FED. ROA	AD DIST. NO. ILI	INOIS FED. AID	PROJEC1	•

#62391

GENERAL NOTES

1- ALL WORK SHALL CONFORM TO THE LATEST NATIONAL ELECTRIC CODE AND IDOT STANDARD SPECIFICATIONS.

2- ALL ELECTRICAL EQUIPMENT AND DEVICES SHALL BE U.L. LISTED AND LABELED.

3- ALL CIRCUIT WIRES SHALL BE LABELED AND IDENTIFIED.

4- REFER TO SHEET STAGE I LIGHTING PLAN FOR ADDITIONAL INFORMATION.

 Λ

5- EVERY THIRD LIGHT POLE ASSEMBLY SHALL BE GROUNDED. SEE TEMPORARY LIGHTING DETAILS SHEET.

6- SERVICE NEUTRAL CONDUCTOR TO BE BONDED AT SERVICE ENTRANCE EQUIPMENT ONLY, PER N.E.C. ARTICLE 250.

LEGEND




TEMPORARY SO FT WOOD LIGHT POLE 15 FT
MAST ARM AND 400W LUMINAIRE 240V,
TYPE MCIII CUTOFF

GROUND ROD %" X 10 FT

COM ED SERVICE
VOLTAGE =
100 AMP 3/C
12 CONNECTORS

12 AWG

100A FUSED DISCONNECT SWITCH
1. THE SWITCH SHALL BE SUITABLE FOR USE
AS SERVICE ENTRANCE EQUIPMENT.



REVISIONS
NAME DATE
KWN 4-11-05

ILLINOIS DEPARTMENT OF TRANSPORTATION
U.S. ROUTE 14 OVER LAWRENCE CREEK

TEMPORARY LIGHTING NOTES, LEGEND, AND POLE MOUNTING DETAIL

SCALE: N.T.S.
DATE: 3-09-05

DRAWN BY: JPG CHECKED BY: GAG

287/TEMPLGHTDTLS

Applied Technologies