

GENERAL NOTES

Reinforcement bars shall conform to the requirements of ASTM A 706 Gr 60. See Special Provisions.

Reinforcement bars designated (E) shall be epoxy coated.

Plan dimensions and details relative to existing plans are subject to nominal construction variations. The Contractor shall field verify existing dimensions and details affecting new construction and make necessary approved adjustments prior to construction or ordering of materials. Such variations shall not be cause for additional compensation for a change in scope of the work, however, the Contractor will be paid for the quantity actually furnished at the unit price bid for the work.

Existing reinforcement shall be cleaned and incorporated into the new construction. Cost included with Concrete Removal.

The Contractor shall ensure the approach slabs and approach shoulders do not settle after removal of the ends of the approaches. If voids are encountered after removal of the deck ends, the Contractor shall pump grout under the approaches to maintain support during removal. Cost included with "Concrete Removal".

INDEX OF SHEETS

1) General Plan & Elevation

- 2) Concrete Removal
- 3) Concrete Details
- 4) Bar Splicer
- 5) For Information Sheet 1959 Approach Pavement Std 2138-1
- 6) For Information Sheet 1984 Approach Shoulder Std 2324-6
- 7) For Information Sheet 1986 Approach Pavement Std 2382-2 (Sh 1 of 2)
- 8) For Information Sheet 1986 Approach Pavement Std 2382-2 (Sh 2 of 2)

- Project Location	Concrete Removal Concrete Superstructure Reinforcement Bars, Epoxy Coated Bar Splicers			Cu. Yd. Cu. Yd. Pound Each	35.2 68.9 6240 64
N					
ELEVATION	F	A.I. RTE.	SECTION	COUNTY	TOTAL SH SHEETS N

TOTAL BILL OF MATERIAL

ELEVATION	F.A.I. RTE.	SECTION	COUNTY	TOTAL SHEETS	SHEET NO.
027 & 0028	70	60-11HB-I	MADISON	10	3
V27 Q V020			CONTRACT	NO. 7	6E25
SHEETS		ILLINOIS FED. A			