



Designation and outside diameter	Wall thickness t	Weight per foot (Lbs./ft.)	Inside volume (yd. <sup>3</sup> /ft.)	
PP12	0.179″	22.60	0.0274	
PP12	0.250''	31.37	0.0267	
PP14	0.250"	36.71	0.0368	
PP14	0.312"	45.61	0.0361	





s = t - 16"





METAL SHELL PILE SHOE ATTACHMENT

(See Note A)

7-*1-1*0

F-MS

COMPANY NAME: PROJECT CONTACT: CLIENT:

#### Note A:

When called for on the plans, the Contractor shall furnish metal shell pile shoes consisting of a single piece conical pile point as shown. The pile shoes shall be cast in one piece steel according to either ASTM A 148 Grade 90-60 or AASHTO M 103 Grade 65-35 and shall provide full bearing over the full circumference of the metal shell pile. The pile shoe shall have tapered leads to assure proper alignment and fitting and shall be secured to the pile with a circumferential weld.



## COMPLETE PENETRATION WELD SPLICE

\* Field fabricated backing ring may be made from pile shell by removing segment to allow reducing circumference and vertically rejoin with partial joint penetration weld.

# Bottom of В ELEVATION

abutment


Note:							
The	metal	shell	piles	shall	be	according	to
ASTM	A 252	2 Gra	de 3.			•	

		HRGreen com	USER NAME =	DESIGNED -	MGH	REVISED			F.A.P. SECTION COUNTY TOTAL SHEET
BLE COL		Illinois Professional Design Firm		CHECKED -	КЈВ	REVISED	STATE OF ILLINOIS	METAL SHELL PILE DETAILS	RIE. SHEETS NO.
	HRGroop	#184-001322	PLOT SCALE =	DRAWN -	WJH	REVISED	DEPARTMENT OF TRANSPORTATION	STRUCTURE NO. 098–0118	22 15BR-1 WHITESIDE 146 78
PRO CLIE DAT PLO PEN PEN	TINGIEEN		PLOT DATE =	CHECKED -	KJB	REVISED		SHEET NO. S-20 OF S-23 SHEETS	CONTRACT NO. 64F19



# CONCRETE ENCASEMENT AT PIERS



### METAL SHELL REINFORCEMENT AT ABUTMENTS