

Notes:

FIXED PIER RETAINER BOLTS

(12 Locations)

Anchor bolts shall be ASTM F1554 all-thread (or an engineer-approved alternate material) of the grade(s) and diameter(s) specified. ASTM A307 grade C anchor bolts may be used in lieu of ASTM F1554 Grade 36 (Fy=36ksi). The corresponding specified grade of AASHTO M314 anchor bolts may be used in lieu of ASTM F1554. Drilled and set anchor bolts shall be installed according to Article 521.06 of the Standard Specifications. Prior to ordering any material, the contractor shall verify in the field all bearing thickness dimensions. Diaphragm removal and reinstallation may be required to facilitate drilling holes. Cost included with Structural

Steel Repair.

Field drilling of existing pier cap for new anchor bolt installation is considered completely included with Anchor Bolts, 1".

All (embedded and separate) bearing plates, side retainers, anchor bolts, nuts, washers and pintles shall be galvanized according to AASHTO M111 or M232 as applicable.



SIDE RETAINER Equivalent rolled angle with stiffeners

will be allowed in lieu of welded plates.

EFK •Moen, LLC	USER NAME = cdl	DESIGNED - CDL	REVISED -		DETAILS	F.A.I SECTION COUNTY TOTAL SHEET
Civil Engineering Design		CHECKED - CTW	REVISED -	STATE OF ILLINOIS		64 95-(1,2)RS-1 WASHINGTON 126 107
303 Fountains Parkway, Suite 240 Fairview Heights, IL 62208	PLOT SCALE = 0:2 ':" / in.	DRAWN - JA	REVISED -	DEPARTMENT OF TRANSPORTATION	STRUCTURE NO. 095–0041 & 095–0042	CONTRACT NO. 76D20
Fairview Heights, IL 62208 ∩ Phone 618-206-4250	PLOT DATE = 6/11/2014	DATE - 6/11/2014	REVISED -		SHEET NO. 5 OF 6 SHEETS	ILLINOIS FED. AID PROJECT



SILICONE JOINT SEALER DETAIL

Note: For estimated locations of polymer concrete nosing replacement, see sheets 3 and 4 of 6.



SECTION A-A

BILL OF MATERIAL

Item	Unit	Total
Anchor Bolts 1''¢	Each	48
Structural Steel Repair	Pound	410
Silicone Joint Sealer, 1.5"	Foot	185
Polymer Concrete	Cu. Ft.	3