



CABLE TRENCH

CONDUIT TRENCH

NOTE
 EXCESS SOIL FROM TRENCH TO BE COMPLETELY REMOVED FROM SITE AS SOON AS PRACTICABLE.
 BLACK DIRT TO BE TAMPED & THOROUGHLY COMPACTED AS SHOWN.

STANDARD METHOD FOR BACKFILLING
 CABLE & CONDUIT TRENCHES IN
 SODDED PARKWAY & LAWNS

REVISION	CITY OF CHICAGO		DEPT. OF STREETS & SANITATION
A	DIVISION OF ELECTRICAL ENGINEERING.		ENGINEER.
B	DRAWN: W. E. HAEP	CHECKED: M. J. Lane	J. O'CONNOR.
C	ENGINE CHARGE: <i>R. B. Stiles</i>		DRG. NO. 579
D	SUPT. OF CONST. <i>W. E. Haep</i>		
E	MATERIALS <i>W. E. Haep</i>		
F	BY <i>W. E. Haep</i>		
G	SIZE: 8 1/2" x 14"	SCALE: N	DATE: 7-14-01
H			