



- HEAVY DUTY INSULATED PULLEY CLEVIS WOOD POLE -BARE COPPER GROUND WIRE EVERY THIRD POLE MESSENGER TIED TO INSULATOR -WITH FACTORY FORMED CABLE TIE - TO LUMINAIRE GROUND CLAMP -NEUTRAL CONDUCTOR AWG BARE COPPER GROUND WIRE PHASE CONDUCTOR - WATERPROOF FUSEHOLDER & FUSE WATERPROOF INSULATION PIERCING TAP CONNECTOR - WATERPROOF FUSEHOLDER AND SOLID NEUTRAL SLUG

TEMPORARY LIGHT POLE ATTACHMENT DETAIL

NOTES:

1. ALL DIMENSIONS IN INCHES (MILLIMETERS) UNLESS OTHERWISE INDICATED

FILE NAME =	USER NAME = gaglianobt	DESIGNED -	REVISED - 08-08-03			TEMPODARY LIGHT BOLE DETAILS	F.A.	SECTION	COUNTY	TOTAL SHEET
W:\diststd\22x34\be800.dgn		DRAWN -	REVISED -	STATE OF ILLINOIS		TEMPORARY LIGHT POLE DETAILS	57	1414 7 R	Coox	5/6 7/2 A
	PLOT SCALE = 50.000 '/ IN.	CHECKED -	REVISED -	DEPARTMENT OF TRANSPORTATION			7,	BE-800	CONTRACT	[NO COT27
	PLOT DATE = 1/4/2008	DATE -	REVISED -		SCALE: NONE	SHEET NO. 1 OF 1 SHEETS STA. TO STA.	FED. RO	DAD DIST. NO. 1 ILLINOIS FED. AI		110.000027