STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths						
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4		
3, 4	1'-5''	1'-11''	2'-1''	2'-4"		
5	1'-9''	2'-5"	2'-7"	2'-11''		
6	2'-1''	2'-11''	3'-1''	3'-6''		
7	2'-9''	3'-10''	4'-2"	4'-8''		
8	3'-8''	5′-1′′	5′-5′′	6'-2''		
9	4'-7"	6'-5''	6′-10′′	7'-9''		

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C


Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Fop bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + 1^l_2 " + thread length


* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length




BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required = 64




STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION




INSTALLATION AND SETTING METHODS

"A": Set bar splicer assembly by means of a template bolt.
"B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.





STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required
	İ	

VOTES

Splicer bars shall be deformed $\overline{\text{with threaded}}$ ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars.

Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See special provision for Mechanical Splicers.

See approved list of bar splicer assemblies and mechanical splicers for alternatives.

BAR SPLICER ASSEMBLY DETAILS STRUCTURE NO. 032-0118

LOCHNER

H.W. LOCHNER, INC. CONSULTING ENGINEERS & PLANNERS 20 NORTH WACKER DRIVE SUITE 1200 CHICAGO, IL 60606 SHEET NO. 17 OF 19 SHEETS

NO. 19 RTE. SECTION COUNTY TOTAL SHEETS NO. 19 * (32,47-4) HBK-4 & G(N) GRUNDY 351 349
TS CONTRACT NO. 66408

FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT

* FAI 80 & FAS 297 / FAU 392