

All cast iron parts shall be gray iron conforming to the requirements of AASHTO M 105, Class 35B.

Bolts, anchor studs, washers and nuts shall conform to the requirements of ASTM A 307 and shall be galvanized according

Downspouts located on the exterior side of a painted steel fascia beam shall be painted with the finish coat specified for


As an alternate, bolts, anchor studs, washers and nuts may be stainless steel according to Article 1006.29(d) of the Standard

Structural steel weldments of equal sections and of the same configuration may be substituted for the cast iron scupper frame. Fillet or full penetration welds shall be used for the weldments. Details shall be submitted to the Engineer for approval. Structural steel weldments shall not be substituted for the cast iron scupper grate. Structural steel frames and downspouts shall be galvanized according to AASHTO M111.

The Contractor shall take appropriate measures to assure that

Cost of the Grate, Frame, Downspout, Anchor Studs, Bolts, Washers and Nuts including complete installation of the scupper shall be paid for at the contract unit price each for Drainage

Alternate fiberglass downspout conforming to ASTM D 2996 with a short-time rupture strength hoop tensile stress of 30,000 psi min. may be used in lieu of the cast iron or steel



ANCHOR STUD DETAIL

BILL OF MATERIAL

ITEM	UNIT	QUANTITY
Drainage Scupper, DS-11	Each	2

DRAINAGE SCUPPER, DS-11 IL 15 OVER UNION DRAINAGE DITCH OVERFLOW WAYNE COUNTY STATION 295+41.00 STRUCTURE NO. 096-0072

TOTAL SHEET NO. COUNTY WAYNE 142 48 23 SHEETS CONTRACT NO. 74238 FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT

10-1-08

DS-11