CONTRACT NO. 89453 F.A.S. SECTION COUNTY S 1458 03-00125-01-GE FULTON STA. TO STA. FED. ROAD DIST. NO. ILLINOIS FED. AID PROJECT SLOPE STEPS DETAIL TYPICAL CROSS-SECTION EMBANKMENT CONSTRUCTION ON SIDEHILL PROPOSED EMBANKMENT LIMIT FOR EMBANKMENT EXISTING GROUNDLINE STEP DEPTH 3 FT. TO 5 FT. PROPOSED SIDEHILL GENERAL NOTES: STEP TREATMENT WIDTH (ARTICLE 205.03). (SEE NOTE 2) 1. Slope Steps will be required for all 12" minimum thickness "sliver fills" and on a fills with a height of 10'. 2. The Step width shall be twice the Step depth but not less than 6 feet. 3. Refer to Article 205.03 for Embankment to be constructed on Hillside or Slopes, or if existing Embankments are to be widened. IDOT DISTRICT DETAIL 205001-D4 REPLACEMENT MATERIAL: STANDARD EMBANKMENT (IN ACCORDANCE WITH SLOPE STEPS 205 OF THE STANDARD SPECIFACATION). DETAIL SCALE: VERT. DRAWN BY

MAURER-STUTZ, INC.

CHECKED BY

SPECIAL DETAIL 1