STANDARD BAR SPLICER ASSEMBLY

| Minimum Lap Lengths | | | | | | | | |
|---------------------------|---------|---------|---------|---------|---------|---------|--|--|
| Bar size to be spliced | Table 1 | Table 2 | Table 3 | Table 4 | Table 5 | Table 6 | | |
| 3, 4 | 1'-5'' | 1'-11'' | 2'-1'' | 2'-4'' | 2'-7'' | 2'-11'' | | |
| 5 | 1'-9'' | 2'-5" | 2'-7'' | 2'-11'' | 3'-3'' | 3'-8'' | | |
| 6 | 2'-1'' | 2'-11'' | 3'-1'' | 3′-6′′ | 3′-10′′ | 4'-5" | | |
| 7 | 2'-9" | 3′-10′′ | 4'-2'' | 4'-8'' | 5′-2′′ | 5′-10′′ | | |
| 8 | 3′-8′′ | 5′-1′′ | 5′-5′′ | 6'-2'' | 6′-9′′ | 7′-8′′ | | |
| 9 | 4'-7'' | 6′-5′′ | 6′-10′′ | 7'-9'' | 8'-7'' | 9′-8′′ | | |

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C

Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Table 5: Epoxy bar, Class C


Table 6: Epoxy bar, Top bar top, Class C

Threaded splicer bar length = min. lap length + $1\frac{1}{2}$ " + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

| Location | Bar size | No. assemblies required | Table for minimum lap length |
|----------|-------------|----------------------------|---------------------------------|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |






INSTALLATION AND SETTING METHODS


"A": Set bar splicer assembly by means of a template bolt. "B" : Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.




STANDARD MECHANICAL SPLICER

| Location | Bar size | No. assemblies required | | |
|----------|-------------|----------------------------|--|--|
| | | | | |
| | | | | |
| | | | | |



BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required = 76



NOTES

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.

All reinforcement shall be lapped and tied to the splicer bars. Bar splicer assemblies shall be epoxy coated according to the requirements

for reinforcement bars. See Section 508 of the Standard Specifications. See approved list of bar splicer assemblies and mechanical splicers for alternatives.

BSD-1

1-27-12

ROKA

Regineering

Zroka Engineering, P.C.
4216 North Hermitage
Chicago, IL 60613 ngineering

| USER NAME = SAW | DESIGNED | - | РММ | REVISED - | |
|---------------------------------|----------|---|-----|-----------|---|
| | CHECKED | - | DAZ | REVISED - | |
| PLOT SCALE = 0:2.0000 ':" / in. | DRAWN | - | SAW | REVISED - | |
| PLOT DATE = 5/2/2013 | CHECKED | - | LAS | REVISED - | |
| | | | | | _ |

STATE OF ILLINOIS **DEPARTMENT OF TRANSPORTATION** BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS S.N. 098-0119 SHEET NO. 17 OF 19 SHEETS

| F.A.S. RTE. | SECTION | | COUNTY | TOTAL SHEETS | SHEE NO. |
|----------------|---------|----------|-----------|-----------------|-------------|
| 200 | 141B-2 | | WHITESIDE | 77 | 42 |
| | | | CONTRACT | NO. (| 54D81 |
| | ILLINOI | S FED. A | D PROJECT | | |