
CONTRACT NO. 62742 STA, TO STA. FED. ROAD DIST. NO. 1 ILLINOIS FED. AID PROJECT 12" (305) MAXIMUM WIDTH EXCEPT AS APPROVED BY THE ENGINEER 12" (305) - WARNING TAPE AS SPECIFIED UNIT DUCT OR OTHER RACEWAY AND WIRING AS PER PLANS. COMPLETE WITH INTERNAL INSULATED EQUIPMENT GROUND WIRE. TYPICAL WIRING IN TRENCH DETAIL ILLINOIS DEPARTMENT OF TRANSPORTATION DATE

30" (762) MINIMUM COVER

N.T.S.

TRIMMED CABLES -COMPRESSION TYPE
COPPER SLEEVE.
(SIZED FOR ACTUAL
NUMBER OF CABLES
AND MFR. SUGGESTED
CRIMP TOOL USED) HEAT-SHRINKABLE CAP-WITH FACTORY APPLIED WATERPROOF SEALANT. (SIZED TO ACCOMMODATE NUMBER OF CABLES). SEALANT TAPE OR INSERT. (ARROUND AND THROUGH CROTCH OF SPLICE). ELECTRIC FEEDER CABLES, SUCH AS UNIT DUCT (SIZE AS NOTED ON CONTRACT) DRAWINGS). -EXPOSED SEALANT NOTE THAT NUMBER OF CABLES IN SPLICE MAY VARY ELECTRIC CABLE TO LUMINAIRE (SIZE AS NOTED ELSEWHERE IN THESE PLANS).

TYPICAL SPLICE DETAIL N.T.S.



MISC. ELECTRICAL DETAILS SHEET A SCALE: VERT. HORIZ. DATE: 1/18/2007 DRAWN BY CHECKED BY

REVISION DATE: 01/01/07

DATE NAME SCALE NAME

BE-702