



WATER MAIN RELOCATION DETAIL
(LOOKING WEST)

NOTES:

WORK TO CONSTRUCT THE WATER MAIN SHALL BE IN ACCORDANCE WITH THE STANDARD SPECIFICATIONS FOR WATER & SEWER MAIN CONSTRUCTION IN ILLINOIS.

WATER MAIN PIPE SHALL BE DUCTILE IRON, CEMENT LINED, MECHANICAL JOINT, CLASS 51, MEETING THE REQUIREMENTS OF ANSI/AWWA A21.51 / C-151.

WATER MAIN FITTINGS SHALL BE DUCTILE IRON, CEMENT LINED, MECHANICAL JOINT PRESSURE RATED FOR 250 PSI AND MEETING THE REQUIREMENTS OF ANSI/AWWA A21.10 / C-110 AND A21.11 / C-111.

DRAWN BY: NV
CHECKED BY: JKC

CAD/.DWG: WMAFM-RELOCATION
DATE: 05/07

REVISIONS	
DATE	BY



PERU MORRIS
ILLINOIS

FAS ROUTE 268 (CH 15) MAIN ST. OVER SOUTH MILL RACE
SECTION 07-00644-00-BR
LASALLE COUNTY

WATER MAIN RELOCATION DETAIL

SCALE: AS NOTED

SHEET 9

FILE NO.: 11670.00Y-1

OF 13