



-
- STYROFOAM VENT BAFFLE. INSTALL BETWEEN EACH RAFTER.
- DOUBLE 2" X 6" HEADER PLATES.
- 18 GA GALVANIZED TIE CONNECTOR. ANCHOR THE RAFTER AND CEILING JOISTS TO THE DOUBLE TOP WALL PLATES. SIMPSON STRONG TIE, MODEL H2 MEETS SPECIFICATIONS
- SOFFIT AND FASCIA MATERIAL SHALL BE 24 GA. STEEL WITH HIDDEN FASTENERS, CONTINUOUSLY VENTED, AND 20 YEAR WARRANTY ON FACTORY FINISH. POSI-LOCK METAL SOFFIT AND FASCIA SYSTEM FROM FABRAL MEETS SPECIFICATIONS. COLOR SHALL BE WHITE. PROVIDE SHOP DRAWINGS FOR SUBSTITUTION. SEE NOTES 6 AND 7.
- FIBERGLASS BATT INSULATION, R-19 IN WALLS, R-30 ABOVE CEILING
- 2 X 6 WALL STUD, 16" O.C.
- AIR AND WATER INFILTRATION BARRIER, TYVEK HOMEWRAP MEETS SPECIFICATIONS
- 1/2" THICK O.S.B. SHEATHING PER NOTE 3
- 3'-0" X 6'-8" HOLLOW CORE INSULATED METAL EXTERIOR DOOR. FRAME PER MANUFACTURER'S SPECIFICATIONS. PAINT DOOR AND FRAME LIGHT GRAY USING EXTERIOR LATEX PAINT PER MANUFACTURER'S FINISHING INSTRUCTIONS. SEE NOTE 4.
- STRUCTURAL EXPOSED FASTENER WALL SYSTEM, 22 GA., GRADE 40 STEEL, EXPOSED FASTENERS, LIFETIME FILM INTEGRITY WARRANTY. 10-YEAR WARRANTY AGAINST EDGE RUST AND ACID RAIN, AND 30-YEAR FADE AND CHALK WARRANTY. MIGHTY-RIB PBR METAL SIDING SYSTEM FROM FABRAL MEETS SPECIFICATIONS. PANELS SHALL BE FASTENED TO SHEATHING USING ZINC PLATED SCREWS WITH A NO. 14 X 1" COMBINATION STEEL AND NEOPRENE WASHER WITH COLOR TO MATCH PANEL. PROVIDE SHOP DRAWINGS FOR SUBSTITUTION. COLOR SHALL BE WHITE. SEE NOTES 6 AND 7.
- CRUSHED ROCK FINISHED GRADE
- 4/0 AWG BARE COPPER PERIMETER GROUNDING CONDUCTOR, 48" BELOW GRADE.
- 1'-6" TYP
- 1'-6" TYP
- 5'-0" TYP
- 3' TYP
- 10"
- 4'-8 1/4"
- 4'-8 1/4"
- 10"
- 11'-0 1/2"
- FRONT ELEVATION
- DEPARTMENT OF TRANSPORTATION
FEDERAL AVIATION ADMINISTRATION
GREAT LAKES REGION
CHICAGO, ILLINOIS
- GLIDE SLOPE
- FOUNDATION AND FRAMING DETAILS
10'X14' WOOD FRAME EQUIPMENT SHELTER
RUNWAY 02

	DATE	DESCRIPTION	JOB	RECEIVE DATE	AMOUNT