

COUNTY TOTAL SHEE SHEETS NO. F.A.I. RTE. SECTION COOK 90/94 ٠ 247 168 STA. TO STA. FED. ROAD DIST. NO. 1 11 LINOIS FED. ALD PROJECT 60A63 • (1919.15, 2021-922 PT1 & PT2) R-2 This detail shows connection of proposed CRC pavement to existing pavement at an existing long term transverse construction joint. 2. Bar splicer assemblies shall be of an IDOT approved type and shall develop in tension at least 125 percent of the yield strength of the lapped reinforcement bars. 3. Bar splicers shall be of the "coupler" type, and shall not have flanges. 4. Splicer rods shall be of minimum 60 ksi yield strength, threaded or coiled full length. 5. All reinforcement bars shall be lapped and tied to the splicer rods or dowel bars. 6. Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. 7. Other systems of similar design may be submitted to the Engineer for approval. Approval shall be based on certified test results from an approved testing laboratory that the proposed bar splicer assembly satisfies the following requirements: A. Minimum Capacity (Tension in ksi) = 1.25 x fy x A(t) B. Minimum \*Pull-out Strength (Tension in ksi) = 1.25 x fs (allow) x A(t) Where: fy = Yield strength of lapped reinforcement bars in ksi. fs(allow) = Allowable tensile stress in lapped reinforcement bars in ksi (Service Load) A(t) = Tensile stress area of lapped reinforcement bars (in<sup>2</sup>). BAR SPLICER ASSEMBLIES STRENGTH REQUIREMENTS Bar Size Splicer Rod Min. Pull-Out Strength Win. Capacity to be Spliced br Dowel Bar Length (kips) (kips) tension tension 2'-0 23.0 9.2 13.3 #6 2'-7" 33.1 #7 3'-5 45.1 18.0 4'-6" 58.9 23.6 #8 #9 5'-9 75.0 30.0 8. Bar splicer assemblies shall be according to Section 508 of the Standard Specifications, except as noted. 9. Reinforcement shall not be paid for separately but included in the cost of PAVEMENT REINFORCEMENT, 14" 10. Connection to long term transverse construction joint work includes the installation of the bar splicers, payment for this work will be included in the cost of CONTINUOUSLY REINFORCED PORTLAND CEMENT CONCRETE PAVEMENTIA". The bars to be drilled and grouted shall not be paid for separately but included in the cost of PORTLAND CEMENT CONCRETE SHOULDERS, 14" 1. See Standard 421001 for details of CRC pavement reinforcment. 2. See Standards 420001 and 420401 for details of joints and tie bars not shown. 3. See Standard 483001 for pcc shoulder details RDT-8 REVISIONS NAME ILLINOIS DEPARTMENT OF TRANSPORTATION DATE F.A.I. 90/94 (DAN RYAN EXPRESSWAY) 63RD STREET TO GARFIELD BLVD (SB LOCAL LANES) ROADWAY DETAILS CONNECTION TO EXISTING LONG TERM TRANSVERSE CONSTRUCTION JOINT SCALE: NONE DRAWN BY: TAI DATE: June 9, 2006 CHECKED BY: PJM