

TYPICAL CONCRETE REMOVAL AND REPLACEMENT

Hatched areas indicate concrete sections to be removed and replaced. Perimeters of concrete removal areas shall be saw cut $\frac{3}{4}$ " prior to the removal of concrete. Reinforcement shall be cut only if required for fitting bolts. Cut reinforcement shall be spliced as directed by the Engineer. Cost shall be included with Concrete Removal.

PSJ

SJB

baliva

PSJ SJB

EXAMINED (

PASSE

0

DESIGNED

CHECKED

CHECKED

REP-2 1-27-2000

DRAWN

JULY 17, 2006

A. Mouri



SUGGESTED TEMPORARY SLAB SUPPORT SYSTEM

(Dimensions are along & beam 18)

after support beam deflects under its own weight.

SLAB SUPPORT DETAILS IL 43 OVER US12/20 COOK COUNTY SN 016-0320