



AECOM

62301 * (2021-922 PT2 ETC 2324.6-1P) R-10

NOTES:

- 1. SEE DRAWING EI-106 FOR ELECTRICAL DUCTBANK
- 2. THE DISTANCE IS MEASURED FROM THE FRONT FACE OF RETAINING WALL TO THE FACE OF DUCTBANK.
- 3. THE HANDHOLE WILL BE INSTALLED CONTRACT 62301.
 THE PLANS SHOW THE ANTICIPATED LOCATIONS
 OF PROPOSED HANDHOLES. THIS SHEET IS INCLUDED
 TO PROVIDE THE CONTRACTOR WITH ANTICIPATED
 EXISTING CONDITIONS. DUCTBANK SHOWN WAS
 INSTALLED IN CONTRACT 62586.
- 4. THE TOP TWO SURVEILLANCE RACEWAYS SHOULD BE STUBBED OUT FROM THE CONCRETE ENCASEMENT AND CAPPED AS SHOWN. THE DUCTBANK REINFORCING REBAR SHOULD ALSO BE EXTENDED OUT FROM THE CONCRETE ENCASEMENT A MINIMUM OF 2 FEET AS SHOWN.
- 5. DUCTBANK WAS LOCATED 5 FEET FROM THE FACE OF WALL TO AVOID CONFLICTS WITH PROPOSED AND FUTURE DRAINAGE STRUCTURES.

EI-108

REVISIONS NAME DATE		ILLINOIS DEPARTMENT OF TRANSPORTATION F.A.I. 90/94 (DAN RYAN FXPRESSWAY)	
		GARFIELD BLVD TO 31ST STREET (NB LOCAL LANES)	
		EXISTING DUCTBANK	
		INSTALLATION DETAILS AT PROPOSED HANDHOLE	
		SCALE: NOT TO SCALE	DRAWN BY: HAR
	-	DATE: June 9, 2006	CHECKED BY: JPC