

 $\sim$ 

 $\sim$ 



AT PARAPET See Section A-A for end treatment of skews > 30°.

## TYPICAL END TREATMENTS

Notes:

The strip seal shall be made continuous and shall have a minimum thickness of  $l_4$ ". The configuration of the strip seal shall match the configuration of the Locking Edge Rails. Open or "webbed" strip seal gland configurations are not permitted. The gland shall be sized for a maximum rated movement of 4 inches. The Locking Edge Rails depicted are conceptual only, except for the minimum dimensions shown. The actual configuration of the Locking Edge Rails and matching strip seal may vary from manufacturer to manufacturer. Flanged edge rails will not be allowed. Locking Edge Rails may be spliced at slope discontinuities.

The manufacturer's recommended installation methods shall be followed. The joint opening and deck dimensions detailed on the superstructure are based on a rolled rail expansion joint. If the Contractor elects to use the welded rail expansion joint, the opening and deck dimensions shall be modified according to the dimensions detailed on this sheet. Required modifications shall be made at no additional cost to the State.

All steel components shall be galvanized after fabrication according to Article 520.03 of the Standard Specifications.

Maximum space between rail segments at stage lines shall be <sup>3</sup><sub>16</sub>", sealed with a suitable sealant.

\*34" \$ x 6" Studs, typ.

Plat

## BILL OF MATERIAL

Foot	96
	Foot

## PREFORMED JOINT STRIP SEAL S.N. 101-0120

T NO. OF HEETS	F.A.P. RTE.	SECTION	COUNTY TOTAL SHEET SHEETS NO.		
	301	(1-1HB-1)D	WINNEBAGO 55 44		
	CONTRACT NO. 64E11				
	ILLINOIS FED. AID PROJECT				