

STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths						
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4		
3, 4	1'-5''	1'-11''	2'-1''	2'-4''		
5	1'-9''	2'-5''	2'-7''	2'-11''		
6	2'-1''	2'-11''	3'-1''	3'-6''		
7	2'-9''	3'-10''	4'-2''	4'-8''		
8	3'-8''	5′-1′′	5'-5''	6'-2''		
9	4'-7''	6′-5″	6'-10''	7′-9″		

Table 1: Black bar, 0.8 Class C

Table 2:Black bar, Top bar lap, 0.8 Class CTable 3:Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C

Threaded splicer bar length = min. lap length + 1_2^{\prime} + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.

Location	Bar size	No. assemblies required	Table for minimum lap length	
Deck Slab	#5	278	3	
Deck/Abut. Diaph.	#6	16	4	
Appr. Slab (Top)	#4	50	4	
Appr. Slab (Bott.)	#5	92	3	
Appr. Footing	#5	80	3	
Abutments	#8	12	4 .	

re <mark>ng ng</mark> anananan sama	Bridge Deck	Approach Slab
Reinforcement Bars	Threaded couplers (E)	Threaded splicer bar (E)

Thr bar	eaded splicer (E) 4'-0''	6'-0''

BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required = 70

	<i>Johnson,</i> CONSU Spri	RS		
DESIGNED:	JDQ	DRAWN:	SJS	
CHECKED:	DCD	CHECKED:	DCD	
BSD-1 11-1-09				

STATE OF ILLINOIS DEPARTMENT OF TRANSPORTATION



INSTALLATION AND SETTING METHODS

"A" : Set bar splicer assembly by means of a template bolt. "B" : Set bar splicer assembly by nailing to wood forms or cementing to steel forms. (E) : Indicates epoxy coating.



yield strength. See special provision for Mechanical Splicers. alternatives.

	Mechanical
	coupler (E)
844444444444444444444444444444444444444	· · · · · · · · · · · · · · · · · · ·
Reinforcement bar —	└─ Reinforcement bar

STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required		
		2. 		

<u>NOTES</u>

Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi

All reinforcement shall be lapped and tled to the splicer bars. Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.

See approved list of bar splicer assemblies and mechanical splicers for

BAR SPLICER ASSEMBLY AND MECHANICAL SPLICER DETAILS STRUCTURE NO. 031-0044

CUTET 10		F.A.P. RTE.	SECTION			COUNTY	TOTAL SHEETS	SHEET NO.	
	SHEET TO	10	38-1			GREENE	59	43	
	OF 20	OF 20 STA. 222+94.00			CONTRACT	NO.	76C15		
		FED. RC	AD DIST. NO.	ILLINOIS	FED,	AID	PROJECT		