DESIGNED S.D.S.


CHECKED C.W.C.

DRAWN D.L.H.

CHECKED S.D.S./C.W.C.

STATE OF ILLINOIS

DEPARTMENT OF TRANSPORTATION



TYPICAL SECTION

BILL OF MATERIAL

ITEM	UNIT	TOTAL
Geotextile Retaining Wall	Sq. Ft.	76

MASON CITY, IOWA DUBUQUE, IOWA AMES, IOWA DUBUQUE, ILLINOIS SPRINGFIELD, ILLINOIS ROCHESTER, MINNESO

SUGGESTED GEOTEXTILE TEMPORARY FORM BRACE SYSTEM DETAIL

±2′-0′′ Wood wedge to support and align strap

1" thick plywood or timber

14" mm steel strap

Plywood or

3" x 4" mm steel strap

timber plan

planks, continuous for lift

TOTAL SHEET SHEET NO. 5 61 20 16 SHEETS F.A.P. 607 129BR KENDALL FEO. ROAD DIST. NO.

Contract #66667

Wedge

Additional compacted material

placed in depression

Reinforcement spacing

re-embedment length

Geotextile Fabric

- 1. Place form brace system on completed reinforcement level; back from the finished fabric face a distance of 13 to 12 the reinforcement spacing.
- Position fabric so that the required re-embedment length extends over the top of the form brace and the design reinforcement width is placed with no slack against the previous level.
- 3. Compact backfill material in lifts to final lift height, create (±3") depression in zone where re-embedment length will be located and place additional height of compacted material against form brace.
- 4. Fold fabric re-embedment length back over form brace into zone where depression was made in backfill and place additional compacted backfill, (±3") to embed fabric and bring to final lift height.
- 5. Pull form brace outward allowing fabric face to slightly readjust to form tight round face and level with plan reinforcement spacing.

GEOTEXTILE WALL CONSTRUCTION PROCEDURE

The geotextile fabric shall have a minimum allowable tensile strength (T min.) of 10 lb./in. as determined by the procedure stated in the Special Provisions. The computations supporting the determination of (T min.) shall be submitted to the engineer for approval.

1" I.D. pipe

1" dia. steel pin

1" I.D. pipe

' dia. steel pin

This is a suggested detail, the Contractor is responsible for the design of the form brace system to be used,

Fabric readjustment

13 to 12 Reinforcement spacing —— Form brace system

Geotextile

Fabric

Zone where re-embedment length will be placed.

Additional backfill

Compacted backfill -

Final lift height

GEOTEXTILE RETAINING WALL

U.S. RTE. 52 OVER WEST AUX SABLE CREEK F.A.P. 607 - SECTION 129BR KENDALL COUNTY STATION 108+07 STRUCTURE NO. 047-2019