

STANDARD BAR SPLICER ASSEMBLY

Minimum Lap Lengths							
Bar size to be spliced	Table 1	Table 2	Table 3	Table 4	Table 5	Table 6	
<i>3, 4</i>	1'-5''	1'-11''	2'-1''	2'-4''	2'-7''	2'-11''	
5	1'-9''	2'-5"	2'-7''	2'-11''	3'-3''	3′-8′′	
6	2'-1''	2'-11''	3'-1''	3′-6′′	3′-10′′	4'-5"	
7	2'-9''	3′-10′′	4'-2''	4'-8''	5′-2′′	5′-10′′	
8	3′-8′′	5′-1′′	5′-5′′	6'-2''	6′-9′′	7′-8′′	
9	4'-7''	6′-5′′	6'-10''	7'-9''	8'-7''	9′-8′′	

Table 1: Black bar, 0.8 Class C

Table 2: Black bar, Top bar lap, 0.8 Class C

Table 3: Epoxy bar, 0.8 Class C

Table 4: Epoxy bar, Top bar lap, 0.8 Class C


Table 5: Epoxy bar, Class C

Table 6: Epoxy bar, Top bar top, Class C

Threaded splicer bar length = min. lap length + 1^{l_2} " + thread length

* Epoxy not required on Bar Splicer Assembly components used in conjunction with black bars.


Location	Bar size	No. assemblies required	Table for minimum			
	SIZE	required	lap length			



INSTALLATION AND SETTING METHODS


"A": Set bar splicer assembly by means of a template bolt.
"B": Set bar splicer assembly by nailing to wood forms or cementing to steel forms.

(E): Indicates epoxy coating.




STANDARD MECHANICAL SPLICER

Location	Bar size	No. assemblies required			
West Abutment	#14	1368			



BAR SPLICER ASSEMBLY FOR #5 BAR ON INTEGRAL OR SEMI-INTEGRAL ABUTMENTS

No. required =



NOTES:

- Splicer bars shall be deformed with threaded ends and have a minimum 60 ksi yield strength.
- 2. All reinforcement shall be lapped and tied to the splicer bars.
- 3. Bar splicer assemblies shall be epoxy coated according to the requirements for reinforcement bars. See Section 508 of the Standard Specifications.
- See approved list of bar splicer assemblies and mechanical splicers for alternatives.

	USER NAME = dunkerleyb	DESIGNED -	EJO	REVISED	STATE OF ILLINOIS	BAR SPLICER ASSEMBLY		SECTION	COUNTY	TOTAL	HEET
1		CHECKED -	ATB	REVISED		STRUCTURE NO. 016-1713	90/94/290	2013-008R	СООК	559	295
	PLOT SCALE = N.T.S.	DRAWN -	BRD	REVISED	DEPARTMENT OF TRANSPORTATION		CONTRACT NO. 60W26				
	PLOT DATE = 9/15/2013	CHECKED - EJO REVISED		REVISED		SHEET NO. S1-45 OF S1-48 SHEETS ILLINOIS		ILLINOIS FED.	FED. AID PROJECT		