



**NOTES:**

1. POLE HEIGHT SHALL BE INCREASED AS NECESSARY TO MAINTAIN A MINIMUM CLEARANCE OF 20' OF AERIAL CABLE OVER ROADWAY AT ALL TIMES
2. GUYS AND ANCHORS ARE SHOWN AS EXAMPLE AND SHALL BE INSTALLED AS NECESSARY TO THE SATISFACTION OF THE ENGINEER
3. TEMPORARY WOOD PANELS SHALL BE SET BACK MINIMUM OF 30 FT FROM EXISTING EDGE OF PAVEMENT AND OUTSIDE THE CLEAR ZONE
4. TRAFFIC MAY NOT USE MEDIAN CROSSOVERS UNTIL TEMPORARY LIGHTING IS OPERATIONAL
5. THE CONTRACTOR SHALL NOTE THERE IS SHALLOW ROCK IN THE VICINITY OF THE TEMPORARY LIGHTING SYSTEM, SEE PLAN AND PROFILE AND CROSS-SECTION SHEETS FOR APPROXIMATE ROCK ELEVATIONS.

**LEGEND**

- ⊗ TEMPORARY LIGHTING UNIT, 50 FT WOOD POLE, CLASS 3 WITH 250W HPS MULTI MOUNT LUMINAIRE
- A— AERIAL CABLE, 2-1/2 NO. 4 ALUMINUM WITH MESSAGE WIRE
- ⊠ TEMPORARY LIGHTING CONTROLLER AND ELECTRIC SERVICE 30A, 240V, 1 PHASE AND 3 WIRE

CONTROL INSTALLATION  
PHOTOCELL RELAY  
(LOCATION TO BE DETERMINED  
TO THE SATISFACTION OF THE  
ENGINEER)

**SCHEDULE OF QUANTITIES**

CODE	ITEM DESCRIPTION	UNIT	QUANTITY
X8410102	TEMPORARY LIGHTING SYSTEM	L SUM	1
X8410118	MAINTENANCE OF TEMPORARY LIGHTING	L SUM	1

