


FOUNDATION DESIGN TABLE

TYPE OF SOIL	DESIGN DEPTH OF FOUNDATION		REINFORCEMENT IN FOUNDATION			
	SINGLE ARM D	TWIN ARM D	SINGLE ARM		TWIN ARM	
			VERT BARS	SPIRAL	VERT BARS	SPIRAL
SOFT CLAY	13'-0" (3,962 m)	15'-0" (4,572 m)	8-#6X12'-6" (3,810 m)	*3X122' (37,186 m)	8-#6X14'-3" (4,343 m)	*3X141' (42,977 m)
MEDIUM CLAY	9'-6" (2,896 m)	10'-9" (3,277 m)	8-#6X9'-0" (2,743 m)	*3X90' (27,432 m)	8-#6X10'-0" (3,048 m)	*3X100' (30,480 m)
STIFF CLAY	7'-0" (2,134 m)	8'-0" (2,438 m)	8-#6X6'-6" (1,981 m)	*3X66' (20,112 m)	8-#6X7'-6" (2,286 m)	*3X76' (23,165 m)
LOOSE SAND	9'-0" (2,743 m)	10'-0" (3,048 m)	8-#6X8'-6" (2,591 m)	*3X85' (25,908 m)	8-#6X9'-6" (2,896 m)	*3X94' (28,651 m)
MEDIUM SAND	8'-3" (2,515 m)	9'-0" (2,743 m)	8-#6X8'-0" (2,438 m)	*3X78' (23,774 m)	8-#6X8'-6" (2,591 m)	*3X85' (25,908 m)
DENSE SAND	7'-9" (2,362 m)	9'-0" (2,743 m)	8-#6X7'-6" (2,286 m)	*3X73' (22,250 m)	8-#6X8'-6" (2,591 m)	*3X85' (25,908 m)
ROCK OR SOLIDIFIED SLAG	5'-0" (1,524 m)	5'-0" (1,524 m)	NONE	NONE	NONE	NONE

NOTES

- ALL DIMENSIONS ARE IN INCHES (MILLIMETERS) UNLESS OTHERWISE SHOWN.
- THE ENGINEER SHALL DETERMINE THE CLASS OF SOIL DURING EXCAVATION AND SELECT THE DESIGN DEPTH OF FOUNDATION FROM THE DESIGN TABLE.
- EXCAVATION OF THE POLE FOUNDATION SHALL BE MADE WITH AN AUGER, 24" (609.6 mm) OR 30" (762.0 mm) IN DIAMETER.
- THE ANCHOR ROD SHALL BE A HOOK ROD TYPE. COLD BENDING OF THE ANCHOR ROD WILL NOT BE ALLOWED. THE RADIUS OF THE HOOK BEND SHALL NOT BE LESS THAN 4 TIMES THE NOMINAL DIAMETER OF THE ANCHOR ROD. A TACK WELDED ANCHOR ROD MAY BE SUBSTITUTED WITH THE APPROVAL OF THE ENGINEER.
- THE ANCHOR BOLTS AND RACEWAYS SHALL BE PROPERLY SECURED IN PLACE BEFORE THE CONCRETE IS PLACED IN THE FORM.
- THE ANCHOR RODS SHALL BE ACCORDING TO ASTM F1554 GRADE 725 (GRADE 105). NUTS SHALL BE HEXAGON NUTS ACCORDING TO ASTM A 194 2H OR ASTM A 563 DH, AND WASHERS SHALL BE ACCORDING TO ASTM F 436.
- THE CONTRACTOR SHALL COORDINATE EXTENSION OF ANCHOR BOLTS ABOVE TOP OF FOUNDATION WITH THE BREAKAWAY DEVICE MANUFACTURER'S REQUIREMENTS. IF LIGHT POLE IS MOUNTED WITHOUT BREAKAWAY DEVICE, ANCHOR BOLTS SHALL PROJECT 2 3/4" (69.9 mm) ABOVE TOP OF THE FOUNDATION. THE CONTRACTOR SHALL CONFIRM ANCHOR BOLT EXTENTION WITH ENGINEER.
- RACEWAYS SHALL PROJECT 1" (25.4 mm) ABOVE THE TOP OF THE FOUNDATION.
- THE CABLE TRENCH SHALL BE BACKFILLED AND FIRMLY COMPACTED BEFORE THE LIGHT IS ERECTED.



BILL OF MATERIAL

MARK	NO.	SIZE	LENGTH	SHAPE
a	10	6	SEE BELOW	—
s	12	4	2,438 m	□
s ₁	3	3	2,286 m	□
v ₁	8	6	0,838 m	—
v ₂				

OFFSET SCHEDULE

PIPE DIAM. d IN.	PILE OFFSET FROM C-MED'N FT.	LENGTH OF BAR a FT.
UP TO 24"	3'-3"	*6 x 5'-3"
27" (609.6 mm) TO 36" (914.4 mm)	3'-9"	5'-9"
42" (1066.8 mm) TO 48" (1219.2 mm)	4'-6"	6'-6"
54" (1371.6 mm) TO 60" (1524.0 mm)	5'-0"	7'-0"
66" (1676.4 mm) TO 72" (1828.8 mm)	5'-6"	7'-6"

ORIENT FOUNDATION TO MINIMIZE LENGTH OF OFFSET.

DESIGNED BY: BAXTER & WOODMAN INC. 11/10/2012
 DRAWN BY: MAC 11/10/2012
 CHECKED BY: MDW 11/10/2012
 DATE: 5-14-12



DESIGNED - DSH	REVISED - 8-3-12 PER IDOT
DRAWN - MAC	REVISED -
CHECKED - MDW	REVISED -
DATE - 5-14-12	FILE - 100751-ba310.sht

VILLAGE OF SKOKIE, ILLINOIS
 F.A.U. ROUTE 1332 E. OAKTON STREET
 FROM F.A.P. 350 U.S. ROUTE 41 (SKOKIE BOULEVARD) TO LOWELL AVENUE
 STREETScape IMPROVEMENTS

LIGHT POLE FOUNDATION OFFSET
 40' (12,192 m) TO 47 1/2' (14,478 m) M.H.
 15" (381 mm) BOLT CIRCLE

F.A.U. RTE. 1332	SECTION 11-02036-00-L5	COUNTY COOK	TOTAL SHEET NO. 26
FED. ROAD DIST. NO. 1 (ILLINOIS)	C-91-149-12	CONTRACT NO. 63737	FED. AID PROJECT 1E-0001889